



JEFFERSON PARISH

DEPARTMENT OF PURCHASING

WWW.JEFFPARISH.NET

JOHN F. YOUNG, JR.
PARISH PRESIDENT

BRENDA J. CAMPOS
DIRECTOR

September 2, 2015

ADDENDUM #2

Bid No.: 50-00114226

Bid Opening Date: September 15, 2015

**For: PURCHASE OF RUBBER FLAPPER CHECK VALVES FOR THE JEFFERSON PARISH
DEPARTMENT OF PUBLIC WORKS – WATER, EAST BANK TREATMENT PLANT**

CLARIFICATIONS:

Please remove the Warranty language from the bid specifications on Page 1 REVISED BID SPECIFICATIONS – ADDENDA #1 Section 2.0 PRODUCT C.

We have found through research that other well branded valves do not offer a warranty anywhere near the 25 years.

C. The flexible disc shall be one piece and precision molded with alloy steel and nylon reinforcement and an integral O-ring style seat for drop tight seating at low pressure. As required by AWWA C508, the flexible disc shall have been independently tested to a minimum of 1,000,000 cycles with no signs of wear, abrasion or cracking and be drop-tight at the conclusion of testing. ~~The flexible disc shall be provided with a 25-year warranty against failure.~~

Sincerely,

Sidney Duffy

Sidney Duffy, Buyer II
Jefferson Parish Purchasing Department

Bidders MUST acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form as indicated. Failure to do so will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.

Updated: September 2, 2015