

This product is a non medical device

FACE MASKS

Filter efficiency:95%


Middle layer:Electret-treated meltblown cloth

High efficiency to filter pollendust and droplet

*Middle layer:Electret-treated meltblown cloth,
High efficiency to filter pollen dust and droplet

Three layers of protection

Inner and outer layer:
PP Spunbond Nonwoven
Filter layer:Meltblown cloth



50PCS

Size About 175x95mm







[Home](#)

[Food](#)

[Drugs](#)

[Medical Devices](#)

[Radiation-Emitting Products](#)

[Vaccines, Blood & Biologics](#)

[Animal & Veterinary](#)

[Cosmetics](#)

Establishment Registration & Device Listing

[FDA Home](#) [Medical Devices](#) [Databases](#)

[New Search](#)

[Back To Search Results](#)

| | |
|---|--|
| Proprietary Name: | Disposable Face Mask |
| Classification Name: | ACCESSORY, SURGICAL APPAREL |
| Product Code: | LYU |
| Device Class: | 1 |
| Regulation Number: | 878.4040 |
| Medical Specialty: | General & Plastic Surgery |
| Registered Establishment Name: | WEIHAI HAI NA BAI CHUAN PHARMACEUTICAL GROUP |
| Registered Establishment Number: | 3016933465 |
| Owner/Operator: | Weihai HAI NA BAI CHUAN PHARMACEUTICAL GROUP |
| Owner/Operator Number: | 10065384 |
| Establishment Operations: | Manufacturer |

Test Report

SL52025269649001TX

Date: June 28, 2020

Page 1 of 4

WEIHAI HAINABAICHUAN PHARMACEUTICAL GROUP CO. LTD
NO.25, DUO SHAN ROAD, WENDENG ECONOMIC DEVELOPMENT ZONE, WEIHAI CITY, SHANDONG PROVINCE

The following sample(s) was/were submitted and identified on behalf of the client as:

Sample Description : (A) Single-use medical face mask

Style No. : Large

Lot No./Batch No. : Not provided

Sample Color : (A) BLUE


Test Performed : Selected test(s) as requested by applicant

Sample Receiving Date : Jun 04, 2020

Testing Period : Jun 04, 2020 - Jun 28, 2020

Test Result(s) : Unless otherwise stated the results shown in this test report refer only to the sample(s) tested, for further details, please refer to the following page(s).

Signed for and on behalf of
SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd Testing Center



Sara Guo (Account Executive)



Dongjing Liu (Authorized Signatory)

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

3rd Building, No.889, Yishan Road, Xuhui District Shanghai, China 200233

t (86-21) 61402666 f (86-21) 64958763

www.sgs.com

中国·上海·徐汇区宜山路889号3号楼 邮编: 200233

t (86-21) 61402666 f (86-21) 64958763

e sgs.china@sgs.com



Test Result

EN 14683:2019+AC:2019 Medical Face Masks-Requirements and Test Methods

Clause 5.2 Performance Requirement

Clause 5.2.2 Bacterial filtration efficiency (BFE)*

(EN 14683:2019 Annex B)

Sample: A

Conditioning Parameters : Minimum of 4 hours at 21.1°C and 85.0% R.H.
 Dimensions of test specimen : 15 cm x 12.7cm
 Test Area : 95cm²
 Test Side : Outside
 Flow Rate : 28.3 L/min
 Positive Control Average : 2162CFU
 Negative Monitor Count : 0 CFU

| | 1# | 2# | 3# | 4# | 5# |
|----------|------|------|------|------|------|
| (BFE), % | 99.9 | 99.9 | 99.9 | 99.9 | 99.9 |

Remark: Performance Requirement: Type I ≥ 95%, Type II ≥ 98%, Type IIR ≥ 98%

* This test standard is not within the accredited scope in SGS Shanghai testing centre, it is carried out by external laboratory accredited by CMA (China Metrology Accreditation).

Clause 5.2.3 Breathability

(EN 14683 :2019+AC:2019 Annex C)

Sample: A

Test number and location : 5 random areas for each specimen (face mask)
 Conditioning Parameters : Minimum of 4 hours at 21±5°C and 85±5% R.H.
 Test Area : 4.9 cm²
 Flow Rate : 8 l/min

| | 1# | 2# | 3# | 4# | 5# |
|---|----|----|----|----|----|
| Differential pressure ΔP (Pa/cm ²) | 38 | 38 | 36 | 37 | 37 |

Remark: Performance Requirement: Type I < 40 Pa/cm², Type II < 40 Pa/cm², Type IIR < 60 Pa/cm²



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com
 SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd. 3rd Building, No.889, Yishan Road, Xuhui District Shanghai, China 200233 t (86-21) 61402666 f (86-21) 64958763 www.sgs.com.cn
 Testing Center: 中国·上海·徐汇区宜山路889号3号楼 邮编: 200233 t (86-21) 61402666 f (86-21) 64958763 e sgs.china@sgs.com

Clause 5.2.4 Splash Resistance

(ISO 22609 :2004, Pressure 16.0 kPa)

| Penetration on inside surface | | | | | | | |
|--------------------------------------|------|------|------------|------|------|------|------|
| 1# | 2# | 3# | 4# | 5# | 6# | 7# | 8# |
| Pass | Pass | Pass | Pass | Pass | Pass | Pass | Pass |
| 9# | 10# | 11# | 12# | 13# | 14# | 15# | 16# |
| Pass | Pass | Pass | Fail | Pass | Pass | Pass | Pass |
| 17# | 18# | 19# | 20# | 21# | 22# | 23# | 24# |
| Pass | Pass | Pass | Pass | Fail | Pass | Pass | Pass |
| 25# | 26# | 27# | 28# | 29# | 30# | 31# | 32# |
| Pass | Pass | Pass | Pass | Pass | Pass | Fail | Pass |
| Number of Pass: | | | 29 | | | | |
| Overall result: | | | Acceptable | | | | |

Remark:

- 1) Performance Requirement Type I: N/A, Type II: N/A, Type IIR: $\geq 16.0\text{kPa}$
- 2) Distance of the medical face mask target area surface to the tip of cannula is $300\pm 10\text{mm}$.
- 3) Condition and Test temperature $(21\pm 5)^{\circ}\text{C}$, relative humidity $(85\pm 10)\%$
- 4) An acceptable quality limit of 4.0% is met for a single sampling plan when 29 or more of the 32 tested specimens show pass results

Clause 5.2.5 Microbial Cleanliness

(EN 14683:2019+AC:2019 Annex D and EN ISO 11737-1:2018)

| | | | | | |
|-------|----|----|----|----|----|
| | 1# | 2# | 3# | 4# | 5# |
| CFU/g | <1 | <1 | 1 | <1 | 5 |


Remark: Performance Requirement: Type I $\leq 30\text{CFU/g}$, Type II $\leq 30\text{CFU/g}$, Type IIR $\leq 30\text{CFU/g}$



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd. 3rd Building, No.889, Yishan Road, Xuhui District Shanghai, China 200233 t (86-21) 61402666 f (86-21) 64958763 www.sgsgroup.com.cn
Testing Center: 300018, No.100, Xiangyin Road, Songjiang District Shanghai, China 201600 t (86-21) 61402666 f (86-21) 64958763 e sgs.china@sgs.com
中国·上海·徐汇区宜山路889号3号楼 邮编: 200233 t (86-21) 61402666 f (86-21) 64958763 e sgs.china@sgs.com

Sample Photo



The statement of conformity in this test report is only based on measured values by the laboratory and does not take their uncertainties into consideration.

End of Report



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com