



JEFFERSON PARISH

DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR

December 6, 2024

ADDENDUM # 1

Bid Number: 50-00146808

Bid Due Date: December 12, 2024 at 2:00 PM
Postponed Date: January 7, 2025 at 2:00 PM

Purchase of Submersible Motor Pumps for the Jefferson Parish Department of Sewerage

Questions & Answer:

- Question:** The specifications provide the KSB model KRT as reference.
On the other hand, the specifications also refer to AIS in the QA – references standards
We just want to confirm that the pump does not have to comply with the AIS or BABA requirements for the manufacturing location of the pump.

Answer: American Iron and Steel and Build America Buy America is not required.

Revision:

- Remove the Bid Specifications and Bid Form in its entirety and replace with the attached Revised Bid Specifications and Bid Form

*****THIS BID HAS BEEN POSTPONED UNTIL JANUARY 7, 2025 AT 2:00 PM*****

****YOU MUST USE THE REVISED BID FORM FOR YOUR BID SUBMISSION****

***PLEASE REMEMBER TO ACKNOWLEDGE THIS ADDENDUM BY NUMBER ON YOUR BID SUBMISSION**

JOSEPH S. YENNI BUILDING - 1221 ELMWOOD PARK BLVD - SUITE 404 - JEFFERSON, LA 70123 - PO BOX 10242 JEFFERSON, LA 70181-0242
OFFICE 504.364-2678

GENERAL GOVERNMENT BUILDING - 200 DERBIGNY ST - SUITE 4400 - GRETNA, LA 70053 - PO BOX 9 - GRETNA - LA 70054
OFFICE 504.364.2678

EMAIL: PURCHASING@JEFFPARISH.GOV

WEBSITE: WWW.JEFFPARISH.GOV



JEFFERSON PARISH

DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR

Sincerely,

A handwritten signature in black ink, appearing to read "Ruby Tran", is written over a horizontal line.

Ruby Tran, Purchasing Specialist II
Jefferson Parish Purchasing Department

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.

JOSEPH S. YENNI BUILDING - 1221 ELMWOOD PARK BLVD - SUITE 404 - JEFFERSON, LA 70123 - PO BOX 10242 JEFFERSON, LA 70181-0242
OFFICE 504.364.2678

GENERAL GOVERNMENT BUILDING - 200 DERBIGNY ST - SUITE 4400 - GRETN, LA 70053 - PO BOX 9 - GRETN - LA 70054
OFFICE 504.364.2678

EMAIL: PURCHASING@JEFFPARISH.GOV

WEBSITE: WWW.JEFFPARISH.GOV

DATE: 12/06/2024

Page: 6

BID NO.: 50-00146808

BID FORM
Non Public Works

All Public Work Projects are required to use the Louisiana Uniform Public Work Bid Form

All prices must be held firm unless an escalation provision is requested in this bid. Jefferson Parish will allow one escalation during the term of the contract, which may not exceed the U.S. Bureau of Labor Statistics National Index for all Urban Consumers, unadjusted 12 month figure. The most recently published figure issued at the time an adjustment is requested will be used. A request must be made in writing by the vendor, and the escalation will only be applied to purchases made after the request is made.

Are you requesting an escalation provision?

YES _____ NO X

MAXIMUM ESCALATION PERCENTAGE REQUESTED X %

INITIAL BID PRICES WILL REMAIN FIRM THROUGH THE DATE OF 03/04/25

For the purposes of comparison of bids when an escalation provision is requested, Jefferson Parish will apply the maximum escalation percentage quoted by the bidder to the period to which it is applied in the bid. The initial price and the escalation will be used to calculate the total bid price. It will be assumed, for comparison of prices only, that an equal amount of material or labor is purchased each month throughout the entire contract.

DELIVERY: FOB JEFFERSON PARISH

INDICATE DELIVERY DATE ON EQUIPMENT AND SUPPLIES

10/15/25

LOUISIANA CONTRACTOR'S LICENSE NO.: (if applicable)

NA

THIS SECTION MUST BE COMPLETED BY BIDDER:

FIRM NAME: J. H. Wright

ADDRESS: 27395 Pollard Rd.

CITY, STATE: Daphne, Alabama ZIP: 36526

TELEPHONE: (251) - 621 - 1491 FAX: ()

EMAIL ADDRESS: lroy@jhwright.com

In the event that addenda are issued with this bid, bidders MUST acknowledge all addenda on the bid form. Bidder must acknowledge receipt of an addendum on the bid form by placing the addendum number as indicated. Failure to acknowledge any addendum on the bid form will result in bid rejection.

Acknowledge Receipt of Addenda: NUMBER: Addendum #1 LR ✓

NUMBER: _____

NUMBER: _____

NUMBER: _____

TOTAL PRICE OF ALL BID ITEMS: \$ 151,175.00

AUTHORIZED SIGNATURE: Lawrence Roy

Lawrence Roy
Printed Name

TITLE: Outside Sales, Louisiana

SIGNING INDICATES YOU HAVE READ AND COMPLY WITH THE INSTRUCTIONS AND CONDITIONS.

NOTE: All bids should be returned with the BID NUMBER and BID OPENING DATE indicated on the outside of the envelope submitted to the Purchasing Department.

DATE: 12/06/2024

Page 7

INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00146808

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
1	2.00	EA	<p>PURCHASE OF SUBMERSIBLE MOTOR PUMPS FOR THE JEFFERSON PARISH DEPARTMENT OF SEWERAGE</p> <p>0010 - KSB MODEL KRT SUBMERSIBLE PUMPS WITH DISCHARGE ELBOW 12x12, WITH A 12 INCH SUCTION AND DISCHARGE, 75 H.P. 1150 RPM, 460/3/60 MOTOR WITH 65 FOOT CORD. RATED FLOW OF 5600 GPM AT 36 TDH, UPPER GUIDE RAIL BRACKETS (2), 3 INCH STAINLESS STEEL RAILS (4), STAINLESS STEEL PUMP CABLES (2) COOLING JACKET IS REQUIRED FOR EACH PUMP</p>	\$ 60,607.50	\$ 121,215
2	1.00	EA	<p>0020 - CUSTOM CONTROLS TECHNOLOGY DUPLEX CONTROL PANEL, 75 H.P., 460/3/60</p> <p>DELIVER TO: PUBLIC WORKS WAREHOUSE 1500 RIVER PARK ROAD BRIDGE CITY, LA 70094</p>	\$ 29,960	\$ 29,960

Non-Public Works Bid Affidavit Instructions

- Affidavit is supplied as a courtesy to Affiants, but it is the responsibility of the affiant to insure the affidavit they submit to Jefferson Parish complies, in both form and content, with federal, state and parish laws.
- Affidavit must be signed by an authorized representative of the entity or the affidavit will not be accepted.
- Affidavit must be notarized or the affidavit will not be accepted.
- Notary must sign name, print name, and include bar/notary number, or the affidavit will not be accepted.
- Affiant **MUST** select either A or B when required or the affidavit will not be accepted.
- Affiants who select choice A must include an attachment or the affidavit will not be accepted.
- If both choice A and B are selected, the affidavit will not be accepted.
- Affidavit marked N/A will not be accepted.
- It is the responsibility of the Affiant to submit a new affidavit if any additional campaign contributions are made after the affidavit is executed but prior to the time the council acts on the matter.

Instruction sheet may be omitted when submitting the affidavit

Non-Public Works Bid

AFFIDAVIT

STATE OF Alabama

PARISH/COUNTY OF Baldwin

BEFORE ME, the undersigned authority, personally came and appeared: Lee Morgan
_____, (Affiant) who after being by me duly sworn, deposed and said that
he/she is the fully authorized Operation Manager of JH Wright (Entity),
the party who submitted a bid in response to Bid Number 50-00146808, to the Parish of
Jefferson.

Affiant further said:

Campaign Contribution Disclosures

(Choose A or B, if option A is indicated please include the required attachment):

Choice A _____ Attached hereto is a list of all campaign contributions, including the date and amount of each contribution, made to current or former elected officials of the Parish of Jefferson by Entity, Affiant, and/or officers, directors and owners, including employees, owning 25% or more of the Entity during the two-year period immediately preceding the date of this affidavit or the current term of the elected official, whichever is greater. Further, Entity, Affiant, and/or Entity Owners have not made any contributions to or in support of current or former members of the Jefferson Parish Council or the Jefferson Parish President through or in the name of another person or legal entity, either directly or indirectly.

Choice B X there are **NO** campaign contributions made which would require disclosure under Choice A of this section.

Debt Disclosures

(Choose A or B, if option A is indicated please include the required attachment):

Choice A _____ Attached hereto is a list of all debts owed by the affiant to any elected or appointed official of the Parish of Jefferson, and any and all debts owed by any elected or appointed official of the Parish to the Affiant.

Choice B X _____ There are **NO** debts which would require disclosure under Choice A of this section.

Affiant further said:

That Affiant has employed no person, corporation, firm, association, or other organization, either directly or indirectly, to secure the public contract under which he received payment, other than persons regularly employed by the Affiant whose services in connection with the construction, alteration or demolition of the public building or project or in securing the public contract were in the regular course of their duties for Affiant; and

[The remainder of this page is intentionally left blank.]

That no part of the contract price received by Affiant was paid or will be paid to any person, corporation, firm, association, or other organization for soliciting the contract, other than the payment of their normal compensation to persons regularly employed by the Affiant whose services in connection with the construction, alteration or demolition of the public building or project were in the regular course of their duties for Affiant.

Signature of Affiant

Lee Morgan

Printed Name of Affiant

SWORN AND SUBSCRIBED TO BEFORE ME

ON THE 7 DAY OF Jan, 2025.

Notary Public

Diana Petersen

Printed Name of Notary

DIANA C. PETERSEN
Notary Public
Alabama State at Large

Notary/Bar Roll Number

My Commission Expires
July 21, 2025

My commission expires _____.



J. H. WRIGHT & ASSOCIATES
P. O. BOX 1085
DAPHNE, AL
PHONE 888-655-7867 / 251-621-1491
FAX 251-621-8111

QUOTATION #

LR1224-02

DATE:

1/7/2025

PREPARED BY:

Lawrence Roy

TO:	<u>Ruby Tran</u>	PROJECT:	<u>50-00146808</u>
COMPANY:	<u>Jefferson Parish</u>	LOCATION:	<u>Gretna, LA</u>
PHONE:	<u>504-364-2687</u>	ENGINEER:	
EMAIL:	<u>ruby.tran@jeffparish.gov</u>	CONTACT:	<u>Ruby Tran</u>
Net 30 Upon			
CREDIT TERMS:	<u>Shipment</u>	SPECS PROVIDED VIA:	<u>Ruby Tran</u>
DELIVERY:	<u>26-30 Weeks ARO</u>	FREIGHT:	<u>Allowed/Delivered</u>

QUANTITY

DESCRIPTION

- | | |
|---|---|
| 2 | Wilco FA30.93D 74HP Submersible Sewage Solids Handling Pumps
Complete with 12" x 12" Base Elbows, Upper Guide Rail Brackets,
3" SS Guide Rail Pipes, & Lifting Chains |
| 1 | Ohio Electric Custom Control Panel Per Spec |

TOTAL SELLING PRICE \$ 151,175

- Notes:
1. Freight is included in the pricing
 2. Wilco's Standard Warranty Applies; OEC's Standard Warranty Applies
 3. Start-Up is included in total selling price
 4. Sales tax will be added unless tax exemption documentation is provided to JHW

- | | |
|---|---|
| 1 | Due to today's highly volatile materials and labor market, pricing is guaranteed for only 30 days from the date of this quote. |
| 2 | Under no circumstances are "Retainage Fees" allowed. |
| 3 | All material is subject to the design engineer's final approval of submittals. |
| 4 | Our prices do not include any Federal, State or Local sales taxes. |
| 5 | All quotations are for material only and do not include any labor or installation unless otherwise noted. |
| 6 | Manufacturer's standard warranty applies to all products. |
| 7 | JHW standard terms and conditions apply (see attached). |
| 8 | Should the services of a collection agency, attorney, or other legal service become necessary for collection, purchaser shall assume responsibility for all expenses accrued in the collection process. |
| 9 | Any material held at JHW's warehouse will be invoiced based on customer's original required date and payment is due per the terms described in "Credit Terms" above. |

The undersigned agrees to, and has the authority to, bind purchaser to the terms and conditions and equipment above:

SIGNATURE: _____

DATE: _____



Customer :
Reference :

Pump Performance Datasheet

Wilo Quotation System 24.3.4

Item number	: 001	Size	: EMU FA30.93D with Motor
Service	:		T34-8/41KEx
Quantity	: 1	Stages	: 1
Quote number	: 2410937	Based on curve number	: FA30.93D 890
		Article Number	:
		Date last saved	: 04 Dec 2024 4:49 PM

Operating Conditions

Flow, rated	: 5,600.0 USgpm
Head, rated (requested)	: 36.00 ft
Head, rated (actual)	: 36.03 ft
Suction pressure, rated / max	: 0.00 / 0.00 psi.g
NPSH available	: Ample
Site Supply Frequency	: 60 Hz

Performance

Speed criteria	: Synchronous
Speed	: 890 rpm
Impeller dia.	: 17.13 in
Impeller diameter, maximum	: 17.76 in
Impeller diameter, minimum	: 13.23 in
Efficiency	: 77.91 %
NPSH required / margin required	: 18.29 / 0.00 ft
Ns (imp. eye flow) / Nss (imp. eye flow)	: 2,823 / 7,886 US Units
MCSF	: 902.6 USgpm
Head max.	: 86.20 ft
Head rise to shutoff	: 139.26 %
Flow, best eff. point	: 4,069.2 USgpm
Flow ratio, rated / BEP	: 137.62 %
Diameter ratio (rated / max)	: 96.45 %
Head ratio (rated dia / max dia)	: 89.89 %
Cq/Ch/Ce/Cn [ANSI/HI 9.6.7-2010]	: 1.00 / 1.00 / 1.00 / 1.00
Selection status	: Acceptable

Liquid

Liquid type	: Water
Additional liquid description	:
Solids Diameter, required / pump max	: 0.00 in / 3.10 in
Solids concentration, by volume	: 0.00 %
Temperature	: 68.00 deg F
Fluid density	: 1.000 / 1.000 SG
Viscosity	: 1.00 cP
Vapor pressure, rated	: 0.34 psi.a

Material

Material selected	: Standard
-------------------	------------

Pressure Data

Maximum working pressure	: 37.31 psi.g
Maximum allowable working pressure	: N/A
Maximum allowable suction pressure	: N/A
Hydrostatic test pressure	: N/A

Driver & Power Data (@Max density)

Driver sizing specification	: Maximum power
Margin over specification	: 0.00 %
Service factor	: 1.00
Power, hydraulic	: 50.94 hp
Power, rated	: 65.38 hp
Power, maximum	: 65.38 hp
Motor rating	: 73.80 hp / 55.03 kW

