

DATE: 10/20/2021

INVITATION TO BID
THIS IS NOT AN ORDER

Page: 5

BID NO.: 50-00136269

JEFFERSON PARISH

PURCHASING DEPARTMENT
P.O. BOX 9
GRETN, LA. 70054-0009
504-364-2678

VENDOR: 27118 BLANK BID COPY VENDOR

BUYER: RSCOTT

As per LSA-RS 47:301 et seq., all governmental bodies are excluded from payment of sales taxes to any Louisiana taxing body. Quotations shall be based on F.O.B. Agency warehouse or jobsite, anywhere within the Parish as designated by the Purchasing Department.

JEFFERSON PARISH reserves the right to cancel all or any part of an order if not shipped promptly. No charges will be allowed for parking or cartage unless specified in quotation. The order must not be filled at a higher price than quoted. JEFFERSON PARISH reserves the right to cancel at any time and for any reason by issuing a THIRTY (30) day written notice to the contractor.

JEFFERSON PARISH is expecting all products to be new and all work to be done in workman-like manner, according to standard practices. Any deviations or alteration from the specifications must be indicated on the bid form for each item and upon request, product data for same must be submitted by the time specified by the Purchasing Department.

DELIVERY: FOB JEFFERSON PARISH

INDICATE DELIVERY DATE ON EQUIPMENT AND SUPPLIES

Local Stock - 1 WEEK ARO

INDICATE STARTING TIME (IN DAYS) FOR CONSTRUCTION WORK

INDICATE COMPLETION TIME (IN DAYS) FOR CONSTRUCTION WORK

In the event that addenda are issued with this bid, bidders MUST acknowledge all addenda on the bid form. Bidder must acknowledge receipt of an addendum on the bid form by placing the addendum number as indicated. Failure to acknowledge any addendum on the bid form will result in bid rejection.

Acknowledge Receipt of Addenda: NUMBER: _____

NUMBER: _____

NUMBER: _____

NUMBER: _____

LOUISIANA CONTRACTOR'S LICENSE NO.: (if applicable) _____

*** ALL BIDDERS MUST COMPLETE SECTION BELOW ***	
FIRM NAME: <u>CED dba IC ELECTRIC</u>	
SIGNATURE: (Must be signed here)	TITLE: <u>SALES</u>
PRINT OR TYPE NAME: <u>CHUCK PUINNO</u>	
ADDRESS: <u>3321 WESTBANK EXPRESSWAY</u>	
CITY, STATE: <u>HARVEY LA</u>	ZIP: <u>70058</u>
TELEPHONE: <u>(504) 341-4281</u>	FAX: <u>(504) 340-3400</u>
EMAIL ADDRESS: <u>CPUINNO@CED-ICELECTRIC.COM</u>	

TOTAL PRICE OF ALL BID ITEMS: \$ 1856.73

INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00136269

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
			Purchase of electrical supplies for the Jefferson Parish Sewerage Department	No QUOTE	No QUOTE
1	1.00	EA	0001 - Board, high density I/O, Tesco Part no. L2000HDIO (0861830)	\$ 12.50	\$ 75.00
2	6.00	EA	0002 - Fuse, one time, 100 amp, 250 volt, Buss catalog no. NON-100 (0855960)	\$ 18.98	\$ 113.88
3	6.00	EA	0003 - Connector, mechanical, uni-tap, AL9CU dual-rated, for no. 10 AWG - 250 KCMIL, Burndy no. BIBD250-4 (086991R)	\$ 405.00	\$ 405.00
4	1.00	EA	0004 - Box, gen rain 200A 240V 4P 3F lte no. NR424 <i>QUOTING EATON # DG324NRK</i> (0874080)	\$ 23.75	\$ 47.50
5	2.00	EA	0005 - Connector, liquid tight, 90 degree, 2 in, malleable iron nylon insulated, for flexible metal conduit, Appleton no. STB-90200 (087722G)	\$ 39.45	\$ 118.35
6	3.00	EA	0006 - Fuse, time delay, 200 amp, 250 volt, fiberglass, dual element, 7-1/8 in long, Gould No. TR200R, Eaton Bussmann no. FRN-R-200 Grainger no. 4A456 (0855320)	\$ 11.90	\$ 285.60
7	24.00	EA	0007 - Relay, IDEC No. RH2B-UL-AC120V, 110-120 volts alternating current, 8-blade, Reynolds no. GPRM-B2C10D3 (0858120)	\$ 11.90	\$ 238.00
8	20.00	EA	0008 - Relay, 24 Volts DC, Idec no. RH2B-UDC24V (085812A)	No QUOTE	No QUOTE
9	18.00	EA	0009 - Pump, sump, 1/2 horsepower, 2 in npt discharge, automatic,		

INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00136269

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
10	4.00	EA	capacity to 135 gpm, 27 ft shut off head 20 ft cord, 115 volt, cast iron body, Myers model no. MW50-11P, MSC no. 39699335 (0570720)	\$ 2.10	\$ 8.40
11	400.00	EA	0010 - Box, outlet, 4 in square, metal, 2-1/8 in deep, (8) 1 in side knockouts, (3) 1/2 in and (2) 3/4 in bottom knockouts, RACO (0873820)	\$.85	\$ 340.00
12	30.00	EA	0011 - Fork, STA-KON, 18-14 AWG wire range, no. 1/4 in stud, insulated, Thomas and Betts no. 14RB-14F (0870520)	\$ 7.50	\$ 225.00
			0012 - Base, relay, Idec no. 5H2B-05 (0858460)		
			Please have items shipped to: Eastbank Warehouse Attention: Curtis McFarland 4901 Jefferson Hwy Suite C Jefferson, LA 70121		



Powering Business Worldwide

Detail Bill of Material

Page 1 of 1

Project Name: JP Disconnect
General Order No:

Negotiation No: FOGX1027X1K1
Alternate No: 0000

Item No.	Qty	Product	Description
1		Safety Switches	Safety Switches
		Catalog No	DG324NRK

Qty List of Materials
1 General Duty Switch - Fusible, 4-Wire, 240 VAC, 200 A, NEMA 3R

Eaton Selling Policy 25-000 applies.

All orders must be released for manufacture within 90 days of date of order entry. If approval drawings are required, drawings must be returned approved for release within 60 days of mailing. If drawings are not returned accordingly, and/or if shipment is delayed for any reason, the price of the order will increase by 1.0% per month or fraction thereof for the time the shipment is delayed.

Seller shall not be responsible for any failure to perform, or delay in performance of, its obligations resulting from the COVID-19 pandemic or any future epidemic, and Buyer shall not be entitled to any damages resulting thereof.

Safety Switch General Information

Global Specifications

System Voltage	240 VAC
Switch Type	Single Throw - General Duty
Poles/Blades	3-Pole
Amperage	200
Protection	Fusible with Neutral
Enclosure Type	NEMA 3R
Fuse Clips	"H" Fuse Clips
Switch Lugs	(1) 6-250
Fungus Proof Treatment	None
Lock-On Provision	None
Fuse Pullers	None
Control Pole	None
Ground Lugs	(2) 14-2
Stainless Mechanism	None
Mill Duty	None

Nameplate

Safety Switch Catalog No.

DG324NRK

The information on this document is created by Eaton Corporation. It is disclosed in confidence and it is only to be used for the purpose in which it is supplied.		PREPARED BY	DATE	Eaton	
		CHUCK PUJINO	10/27/2021		
		APPROVED BY	DATE	JOB NAME	JP Disconnected

NEG-ALT Number P00X1027X1K1-0000	VERSION		DWG SIZE	C.O.	TYPE	DESIGNATION	DRAWING TYPE	SHEET
	REVISION	1.0, 1.3						
	0		A			Safety Switch General Information	Customer Appr.	1 of 1

