



CENTRALBIDDING
FROM CENTRAL AUCTION HOUSE

**5000130298 ONE TIME PURCHASE OF TRASH PUMPS, 6 INCH SELF
PRIMING, TRAILOR MOUNT FOR THE JEFFERSON PARISH SEWERAGE
DEPARTMENT.**

Jefferson Parish Government

Project documents obtained from www.CentralBidding.com

13-May-2020 08:19:10 AM



Bid Number 50 - 130298

**ONE TIME PURCHASE OF TWO TRASH PUMPS, 6 INCH SELF PRIMING,
TRAILER MOUNT FOR JEFFERSON PARISH SEWERAGE DEPARTMENT.**

MAY 14, 2020 AT 2:00 PM

ATTENTION VENDORS!!!

**Please review all pages and respond accordingly, complying with all provisions
in the technical specifications and Jefferson Parish Instructions for Bidders and
General Terms and Conditions. All bids must be received in the Purchasing
Department by the bid due date and time.**

**Jefferson Parish Purchasing Department
200 Derbigny Street
General Government Building, Suite 4400
Gretna, LA 70053
Donna Reamey
Dreamey@Jeffparish.net
504-364-2684**



JEFFERSON PARISH

DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR

PURCHASING DEPARTMENT ANNOUNCEMENT

Due to Covid-19 safety precautions, all public bid openings have been suspended. The bid opening will continue and be made available via phone conference. Advertised bids will be accepted through Central Bidding or manual submission.

Manually-submitted bids will only be accepted from 1:30 – 1:59 p.m. on the day of the bid opening or by appointment. If submitting on the day of the bid opening, bidders must submit at the General Government Building. The Purchasing Department will have a table set up to receive sealed bids at the entrance inside of the building.

The bid opening will be made available by calling the following:

Dial-in Number: (504) 323-1800

Meeting ID: 181357

The bid opening will begin at 2:30 p.m.

While the Purchasing Department is closed to the public, if you have any questions, please contact the department at (504) 364-2678 or e-mail purchasing@jeffparish.net for assistance.

GENERAL GOVERNMENT BLDG. – 200 DERBIGNY ST., SUITE 4400, GRETN, LA 70053
OFFICE 504.364.2678

JOSEPH S. YENNI BLDG. – 1221 ELMWOOD PARK BLVD., SUITE 404, JEFFERSON, LA 70123
OFFICE 504.364.2678
EMAIL: PURCHASING@JEFFPARISH.NET WEBSITE: WWW.JEFFPARISH.NET

**SPECIFICATIONS
6 inch X 6 inch SELF-PRIMING HORIZONTAL SEWAGE PUMP
JEFFERSON PARISH
DEPARTMENT OF SEWERAGE**

- **GENERAL**

Vendor shall furnish two (2) Thompson 6 inch self-priming trailer mounted trash pumps, Model No. 6HT-DIST-4LE2T, or approved equal. The pumps shall be supplied by the factory authorized Thompson Pump agent for Jefferson Parish, Louisiana, or for the brand they are bidding. Any bids submitted for other pump manufacturers must include in their bid all information needed to fully demonstrate complete compliance with the requirements of these specifications. It will be the bidder's responsibility to provide adequate information necessary for complete evaluation of their proposed equipment. Jefferson Parish shall be the sole judge as to the equality of the alternate manufacturer's offering. Jefferson Parish reserves the right to reject any bids that are incomplete or do not demonstrate that they are equal to the requirement of these specifications.

- **GENERAL DESCRIPTION**

The unit shall be a 6-inch portable horizontal self-priming centrifugal trash pump driven by a water-cooled diesel engine. The pump shall be self-priming and capable of handling large volumes of air, water, and solids. End-suction centrifugal pumps requiring add-on systems for priming will not be accepted. The unit shall be a Thompson model 6HT-DIST-4LE2T or approved equal.

- The complete pump package shall be manufactured in a plant that is registered to ISO9001:2008 and a copy of the Certificate shall be provided with the bid submittal. Bids submitted without the Certificate will be rejected.
- The pump shall be designated and manufactured in conformance with CPB / AEM standards.

- **ISUZU DIESEL ENGINE**

- The engine shall be a four cylinder, four cycle, water-cooled, turbo charged, Final Tier IV diesel engine, Isuzu model 4LE2T, or equal. It shall be capable of producing 40 continuous duty horsepower at 1,800 rpm.
- The engine shall drive the pump via an elastomeric torsion drive coupling.
- The engine shall have an industrial type battery with 175-amp hour rating and minimum 990 cold-cranking amps, with 175 amp reserve, mounted in a lockable frame.
- A 12-volt starter and alternator charging system shall be provided.
- Engine shall have a hospital grade silencer muffler.
- Engine shall have an electronic type governor.
- Engine shall have variable speed throttle control.
- Engine shall have safety shutdown switches for low oil pressure and high coolant temperature.

BID SPECIFICATIONS FOR BID # 50-130298

- An instrument panel shall be provided in the enclosure and mounted on rubber isolators.
- Instrument panel shall contain the following instrumentation and controls: key switch, tachometer, hour meter, oil pressure gauge, water temperature gauge, and charge indicator lamp.

• CENTRIFUGAL PUMP

- The centrifugal pump shall be a 6 inch x 6 inch horizontal self-priming centrifugal sewage pump model J6-250-TWG manufactured by Thompson Pump, or approved equal.
- The volute shall be integrally cast in the pump casing. Volute and pump casing shall be constructed of cast iron of no lesser grade than class 30.
- The centrifugal pump shall contain a self-cleaning priming passage (re-prime port) positioned tangentially to the fluid flow path to prevent plugging. Re-prime port designs that include conduits positioned directly in the fluid flow path will not be accepted.
- The impeller shall be two-vane, non-clogging, balanced, semi-open, with full rear shroud, ductile iron, and shall incorporate rear-equalizing vanes to reduce axial loading and prolong seal and bearing life.
- The pump shaft shall be made of SAE 4140 alloy steel. A shaft sleeve composed of 304 stainless steel shall be fitted to the shaft to protect the shaft from wear from the mechanical seal and lip seal.
- The mechanical seal shall be a single, inside mounted, non-pusher type with self-adjusting elastomeric bellows. The seal faces shall be constructed of Tungsten Carbide. All other seal components shall be 304 stainless steel and viton rubber. Neither outside mounted seals or packing will be accepted.
- The seal chamber shall have a tapered bore design, which allows removal of solids and entrained gases from behind the impeller. Seal housing shall be designed to provide adequate lubrication to the seal faces during extended periods of pump dry running. Seal housing shall provide grease lubrication to the seal.
- The pump shaft shall be supported by two bearings of ample size and proper design to withstand typical axial and radial loading imposed on the bearings during normal operation. Bearings shall be grease lubricated.
- The pump shall be equipped with a replaceable wear plate to protect the pump casing from wear. The wear plate shall be equipped with abrasion resistant rubber facing to extend service life.
- The pump shall have a back pullout design allowing the removal of the entire rotating assembly as a unit from the pump casing.
- The pump shall be equipped with a front cleanout cover allowing access to the impeller for removing trash or debris without disturbing the piping. Units not meeting this requirement will not be accepted.
- The pump shall incorporate a full flow suction non-return valve to retain liquid in the suction line to eliminate re-priming with each cycle. The suction

BID SPECIFICATIONS FOR BID # 50-130298

non-return valve shall be a weighted flapper style valve constructed of cast-iron and two-ply nitrile rubber with nylon reinforcement.

- The pump shall incorporate a drain cover for draining the pump casing in freezing weather. The cover shall be removable without the need of special tools.
- The pump shall be capable of delivering 1,300 gallons per minute at 1,800 rpm.
- The pump shall be capable of generating a closed discharge valve (shutoff) head of no less than 84 feet at 1,800 rpm.
- Centrifugal pump shall be capable of handling up to 3-inch diameter non-compressible spherical solids.
- Centrifugal pump shall be capable of fully self-priming on its own with a 25-ft static suction lift within two minutes when the pump is pre-filled with water.
- The pump shall be furnished with a liquid-filled vacuum gauge for system diagnostics.
- The pump inlet shall be equipped with a 6 inch MNPT fitting.
- The pump outlet shall be equipped with a 6 inch, 90° elbow and 6 inch MNPT fitting.
- A 6 inch FNPT strainer shall be provided.

• MOUNTING FRAME

- The complete power unit shall be mounted on a combination frame/single wall fuel tank constructed of tubular steel, approximate length 90 inches, approximate width 48 inches, with a fuel capacity of 62 US gallons.
- The frame shall incorporate an integral lifting bail capable of lifting the entire unit.
- Fuel tank shall have two clean-out ports located at opposite ends of the tank.
- Fuel tank shall have a removable basket strainer mounted in the fill port and a lockable cap.

• TRAILER

- The complete pump set shall be factory mounted on a site trailer meeting NHTSA, DOT Part 571 standards 108, 119, and 120.
- Trailer shall include the following:
 - Single removable axle with leaf spring suspension
 - Two ST225/75R15-D tires.
 - Removable tongue assembly with 3 inch adjustable lunette eye hitch and safety chains.
 - Removable steel diamond plate fenders.
 - Lashing rings.
 - One top wind swivel 15 inch retractable height tongue-mounted jack stand.
 - Two front and two rear stabilizing stands.
 - DOT light package including stop, turn, tail, and side marker lights, and license bracket.

BID SPECIFICATIONS FOR BID # 50-130298

- **PAINTING**

- A minimum 1-2 mil thick layer of Industrial Acrylic Enamel primer shall be applied to the entire pump set prior to the finish coat. A minimum 1-2 mil thick layer of TPM Blue Industrial Acrylic Enamel Paint shall be applied over the primer coat.

- **WARRANTY**

- The manufacturer of the pumping unit shall warrant for a period of one year from the date of shipment that the entire unit and all equipment therein shall be free from defects in design, material, and workmanship.

- **TESTING**

- The complete pump set shall be factory tested according to ANSI/HI 1.6-1994 by a certified quality technician. A test report shall be submitted to the Customer prior to acceptance.

- **MANUALS**

- One complete set of operation and maintenance manuals, stored inside a rainproof document box, shall be furnished with the unit.

DATE: 4/28/2020
BID NO.: 50-00130298

INVITATION TO BID
THIS IS NOT AN ORDER

Page: 1

JEFFERSON PARISH

PURCHASING DEPARTMENT
P.O. BOX 9
GRETNA, LA. 70054-0009
504-364-2678

BUYER: DREAMEY@jeffparish.net

BIDS WILL BE RECEIVED IN THE WEST BANK PURCHASING DEPT, SUITE 4400, JEFFERSON PARISH GENERAL GOVERNMENT BUILDING, 200 DERBIGNY STREET, GRETNA, LA 70053 UNTIL 2:00 PM, 5/14/2020 AND PUBLICLY OPENED THEREAFTER.

For convenience, bidders may also submit bids in the East Bank Purchasing Department, Suite 404, Jefferson Parish Joseph S. Yenni Building, 1221 Elmwood Park Blvd., Jefferson LA 70123. However, if submitting bids on the day of bid opening, bidders must submit at the West Bank location only. All bids will be publicly opened at the West Bank location.

At no charge, bidders may also submit via Jefferson Parish's electronic procurement page by visiting www.jeffparishbids.net to register for this free site. Additional instructions are included in the text box highlighting electronic procurement.

LATE BIDS WILL NOT BE ACCEPTED

Unless submitting via online (see Page 3), each bid must be submitted in a sealed envelope bearing on the outside; the name of the Bidder, his address, and the name of the project for which the bid is submitted and the bid number.

NOTE: ONLY BIDS WRITTEN IN INK OR TYPEWRITTEN, AND PROPERLY SIGNED BY A MEMBER OF THE FIRM OR AUTHORIZED REPRESENTATIVE, WILL BE ACCEPTED. PENCIL AND/OR PHOTOSTATIC FIGURES OR SIGNATURES SHALL RESULT IN BID REJECTION.

INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS

THE FOLLOWING INSTRUCTIONS APPLY TO ALL BIDS

All bids submitted are subject to these instructions and general conditions and any special conditions and specifications contained herein, all of which are made part of this bid proposal reference. By submitting a bid, vendor agrees to comply with all provisions of Louisiana Law as well be in compliance with the Jefferson Parish Code of Ordinances, Louisiana Code of Ethics, applicable Jefferson Parish ethical standards and Jefferson Parish Resolution No. 113646 and/or Resolution No. 113647.

Jefferson Parish adheres to the Louisiana Code of Governmental Ethics, contained in Louisiana Revised Statutes Annotated, R.S. 42:1101, et seq. Vendor/Proposer by this submission, warrants that there are no "conflicts of interest" related to this procurement that would violate applicable Louisiana Law. Violation of the Louisiana Code of Governmental Ethics may result in rescission of contract, permit or licenses, and the imposition of fines and/or penalties, without contractual liability to the public in accordance with applicable law.

All vendors submitting bids should register as a Jefferson Parish vendor if not already yet registered. Registration forms may be downloaded from <http://purchasing.jeffparish.net> and by clicking on Vendor Information. Current W-9 forms with respective Tax Identification numbers and vendor applications may be submitted at any time; however, if your company is not registered and/or a current W-9 form is not on file, vendor registration is mandatory. Vendors may experience a delay in payment if your company is not a registered vendor with Jefferson Parish.

All quotations shall be based on F.O.B. Agency warehouse or job site, anywhere within the Parish as designated by the Purchasing Department. This provision does not apply to public works projects

JEFFERSON PARISH requires all products to be new (current) and all work must be performed according to standard practices for the project. Unless otherwise specified, no aftermarket parts will be accepted. Unless otherwise specified, all workmanship and materials must have at least one (1) year guaranty, in writing, from the date of delivery and/or acceptance of the project. Any deviations or alterations from the specifications must be indicated and/or supporting documentation supplied with bid submission.

Bidders should submit all questions in writing via email to the buyer's email address as indicated above, no later than Five (5) working days prior to the bid opening. Bid numbers should be mentioned in all requests. If submitting online, vendors may send questions via the E-Procurement site no later than Five (5) working days prior to the bid opening.

If this bid requires a pre-bid conference (see Additional Requirements section), bidders are advised that such conference will be held to allow bidders the opportunity to identify any discrepancies in the bid specifications and seek further clarification regarding instructions. The Purchasing Department will issue a written response to bidders' questions in the form of an Addendum. Please note that all official communication will be expressed in the form of an addendum.

Visit our website at [HTTP://PURCHASING.JEFFPARISH.NET](http://PURCHASING.JEFFPARISH.NET)

DATE: 4/28/2020

BID NO.: 50-00130298

Page: 2

All formal Addenda require written acknowledgement on the bid form by the bidder. Failure to acknowledge an Addendum on the bid form shall cause the bid to be rejected. JEFFERSON PARISH reserves the right to award bid to next lowest responsive and responsible bidder in this event.

JEFFERSON PARISH will accept one price for each item unless otherwise indicated. Two or more prices for one item will result in bid rejection. Bidders are required to complete, sign and return the bid form and/or complete and return the associated line item pricing forms as indicated. Vendors must not alter the bid forms. Doing so will cause the bid to be rejected.

A corporate resolution or written evidence of the individual signing the bid having such authority must be submitted with the bid. Failure to comply will cause bid to be rejected. For corporate entities, such written evidence may be a printout of the Louisiana Secretary of State's website listing the signatory as an officer. Such printout shall be included with the bid submission. Bids submitted by Owners or Sole Proprietorships must include certification that he or she owns the entity for which the bid is signed. This documentation must be submitted with the bid. Failure to do so will result in bid rejection.

NOTE: A sample corporate resolution can be downloaded from our website <http://purchasing.jeffparish.net> or you may provide your own document. A sample certification of sole proprietorship can also be downloaded from our website <http://purchasing.jeffparish.net> or you may provide your own document.

INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS

A. AWARD OF CONTRACT: JEFFERSON PARISH reserves the right to award contracts or place orders on a lump sum or individual item basis, or such combination, as shall in its judgment be in the best interest of JEFFERSON PARISH. Every contract or order shall be awarded to the **LOWEST RESPONSIVE AND RESPONSIBLE BIDDER**, taking into consideration the **CONFORMITY WITH THE SPECIFICATIONS** and the **DELIVERY AND/OR COMPLETION DATE**. **SPLIT AWARDS MADE TO SEVERAL VENDORS WILL ONLY BE GRANTED TO THOSE DEEMED RESPONSIVE AND RESPONSIBLE.**

All bid prices shall remain valid for 45 days. Jefferson Parish and the lowest responsive and responsible bidder(s) by mutual written consent may mutually agree to extend the deadline for award by one (1) or more extensions of thirty (30) calendar days.

PROTESTS: Only those vendors that submit bids in response to this solicitation may protest any element of the procurement, in writing to the Director of the Purchasing Department. Written protest must be received within 48 hours of the release of the bid tabulation by the Purchasing Department. After consultation, the Parish Attorney's Office will then respond to protests in writing. (For more information, please see Chapter 2, Article VII, Division 2, Sec. 2-914.1 of the Jefferson Parish Code of Ordinances.)

PREFERENCE: Unless federal funding is directly spent by Jefferson Parish for this purchase, preference is hereby given to materials, supplies, and provisions produced, manufactured or grown in Louisiana, quality being equal to articles offered by competitors outside the state. "LSA – R.S. 38:2251-2261"

B. USE OF BRAND NAMES AND STOCK NUMBERS: Where brand names and stock numbers are specified, it is for the purpose of establishing certain minimum standards of quality. Bids may be submitted for products of equal quality, provided brand names and stock numbers are specified. Complete product data may be required prior to award.

C. CANCELLATION OF CONTRACT: JEFFERSON PARISH reserves the right to cancel all or any part if not shipped promptly. No charges will be allowed for parking or cartage unless specified in quotation. The order must not be filled at a higher price than quoted. JEFFERSON PARISH reserves the right to cancel any contract at anytime and for any reason by issuing a THIRTY (30) day written notice to the contractor.

For good cause and as consideration for executing a contract with Jefferson Parish, vendor conveys, sells, assigns and transfers to Jefferson Parish or its assigns all rights, title and interest in and to all causes of action it may now or hereafter acquire under the antitrust laws of the United States and the State of Louisiana, relating to the particular good or services purchased or acquired by Jefferson Parish.

D. PRICES: Jefferson Parish is exempt from paying sales tax under LSA-R.S. 47:301 (8)(c). All prices for purchases by Jefferson Parish of supplies and materials shall be quoted in the unit of measure specified and unless otherwise specified, shall be exclusive of state and Parish taxes. The price quoted for work shall be stated in figures. In the event there is a difference in unit prices and totals, the unit price shall prevail.

Quantities listed are for bidding purposes only. Actual requirements may be more or less than quantities listed.

Bidders are not to exclude from participation in, deny the benefits of, or subject to discrimination under any program or activity, any person in the United States on the grounds of race, color, national origin, or sex; nor discriminate on the basis of age under the Age Discrimination Act of 1975, or with respect to an otherwise qualified handicapped individual as provided in Section 504 of the Rehabilitation Act of 1973, or on the basis of religion, except that any exemption from such prohibition against discrimination on the basis of religion as provided in the Civil Rights Act of 1964, or Title VI and VII of the Act of April 11, 1968, shall also apply. This assurance includes compliance with the administrative requirements of the Revenue Sharing final handicapped discrimination provisions contained in Section 51.55 (c), (d), (e), and (k)(5) of the Regulations. New construction or renovation projects must comply with Section 504 of the 1973 Rehabilitation Act, as amended, in accordance with the American National Standard Institute's specifications (ANSI A17.1-1961).

Jefferson Parish and its partners as the recipients of federal funds are fully committed to awarding a contract(s) to firm(s) that will provide high quality services and that are dedicated to diversity and to containing costs. Thus, Jefferson Parish strongly encourages the involvement of minority and/or woman-owned business enterprises (DBE's, including MBE's, WBE's and SBE's) to stimulate participation in procurement and assistance programs.

DATE: 4/28/2020

BID NO.: 50-00130298

INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS

Page: 3

The purpose and intention of this invitation to bid is to afford all suppliers an equal opportunity to bid on all construction, maintenance, repair, operating supplies and/or equipment listed in this bid proposal. JEFFERSON PARISH WILL ACCEPT ONE BID ONLY FROM EACH VENDOR. Items bid must meet specifications.

Advertised bids will be tabulated and a copy of the tabulation will be forwarded to each responding bidder.

IN ACCORDANCE WITH STATE REGULATIONS JEFFERSON PARISH OFFERS ELECTRONIC PROCUREMENT TO ALL VENDORS

This electronic procurement system allows vendors the convenience of reviewing and submitting bids online. This is a secure site and authorized personnel have limited read access only. Bidders are encouraged to submit electronically using this free service; while the website accepts various file types, one single PDF file containing all appropriate and required bid documents is preferred. Bidders submitting uploaded images of bid responses are solely responsible for clarity. If uploaded images/documents are not legible, then bidder's submission will be rejected. Please note all requirements contained in this bid package for electronic bid submission.

Please visit our E-Procurement Page at www.jeffparishbids.net to register and view Jefferson Parish solicitations. For more information, please visit the Purchasing Department page at <http://purchasing.jeffparish.net>.

The general specifications for construction projects and the purchase of materials, services and/or supplies are those adopted by the JEFFERSON PARISH Council by Resolution No. 113646 or 113647 dated 12/09/09. The general conditions adopted by this resolution shall be considered as much a part of this document as if they were written wholly herein. A copy may be obtained from the Office of the Parish Clerk, Suite 6700, Jefferson Parish General Government Building, 200 Derbigny Street, Gretna, LA 70053. You may also obtain a copy by visiting the Purchasing Department webpage at <http://purchasing.jeffparish.net> and clicking on Online Forms.

ADDITIONAL REQUIREMENTS FOR THIS BID

PLEASE MATCH THE NUMBERS PRINTED IN THIS BOX WITH THE CORRESPONDING INSTRUCTIONS BELOW.

13, 15

1. All bidders must attend the MANDATORY pre-bid conference and will be required to sign in and out as evidence of attendance. In accordance with LSA R.S. 38:2212(l), all prospective bidders shall be present at the beginning of the MANDATORY pre-bid conference and shall remain in attendance for the duration of the conference. Any prospective bidder who fails to attend the conference or remain for the duration shall be prohibited from submitting a bid for the project.
2. Attendance to this pre-bid conference is optional. However, failure to attend the pre-bid conference shall not relieve the bidder of responsibility for information discussed at the conference. Furthermore, failure to attend the pre-bid conference and inspection does not relieve the successful bidder from the necessity of furnishing materials or performing any work that may be required to complete the work in accordance with the specification with no additional cost to the owner.
3. Contractor must hold current applicable JEFFERSON PARISH licenses with the Department of Inspection and Code Enforcement. Contractor shall obtain any and all permits required by the JEFFERSON PARISH Department of Inspection and Code Enforcement. The contractor shall be responsible for the payment of these permits. All permits must be obtained prior to the start of the project. Contractor must also hold any and all applicable Federal and State licenses. Contractor shall be responsible for the payment of these permits and shall obtain them prior to the start of the project.
4. A LA State Contractor's License will be required in accordance with LSA R.S. 37-2150 et. seq. and such license number will be shown on the outside of the bid envelope. Failure to comply will cause the bid to be rejected. Additionally if submitting the bid electronically, then the license number must be entered in the appropriate field in the Electronic Procurement system. Failure to comply will cause the bid to be rejected.
5. It is the bidder's responsibility to visit the job site and evaluate the job before submitting a bid.
6. Job site must be clean and free of all litter and debris daily and upon completion of the contract. Passageways must be kept clean and free of material, equipment, and debris at all times. Flammable material must be removed from the job site daily because storage will not be permitted on the premises. Precautions must be exercised at all times to safeguard the welfare of JEFFERSON PARISH and the general public.

INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS

7. **PUBLIC WORKS BIDS:** All awards for public works in excess of \$5,000.00 will be reduced to a formal contract which shall be recorded at the contractor's expense with the Clerk of Court and Ex-Officio Recorder of Mortgages for the Parish of Jefferson. A price list of recordation costs may be obtained from the Clerk of Court and Ex-Officio Recorder of Mortgages for the Parish of Jefferson. All awards in excess of \$25,000.00 will require both a performance and a payment bond. Unless otherwise stated in the bid specifications, the performance bond requirements shall be 100% of the contract price. Unless otherwise state in the bid specifications, the payment bond requirements shall be 100% of the contract price. Both bonds shall be supplied at the signing of the contract.
8. **NON-PUBLIC WORKS BIDS:** A performance bond will be required for this bid. The amount of the bond will be 100% of the contract price unless otherwise indicated in the specifications. The performance bond shall be supplied at the signing of the contract.
9. **NON-PUBLIC WORKS BIDS:** A payment bond will be required for this bid. The amount of the bond will be 100% of the contract price unless otherwise indicated in the specifications. The payment bond shall be supplied at the signing of the contract.
10. All bidders must comply with the requirements stated in the attached "Standard Insurance Requirements" sheet attached to this bid solicitation. Failure to comply with this instruction will result in bid rejection.
11. A bid bond will be required with bid submission in the amount of 5% of the total bid, unless otherwise stated in the bid specifications. Acceptable forms shall be limited to cashier's check, certified check, or surety bid bond. All sureties must be in original format (no copies) If submitting a bid online, vendors must submit an electronic bid bond through the respective online clearinghouse bond management system(s) as indicated in the electronic bid solicitation on Central Auction House. No scanned paper copies of any bid bond will be accepted as part of the electronic bid submission.
12. This is a requirements contract to be provided on an as needed basis. JEFFERSON PARISH makes no representations on warranties with regard to minimum guaranteed quantities unless otherwise stated in the bid specifications.
13. Freight charges should be included in total cost when quoting. If not quoted FOB DELIVERED, freight must be quoted as a separate item. Bid may be rejected if not quoted FOB DELIVERED or if freight charges are not indicated on bid form.
14. **PUBLIC WORKS BIDS - Completed, Signed and Properly Notarized Affidavits Required;** This applies to all solicitations for construction, alteration or demolition of public buildings or projects, in conformity with the provisions contained in LSA-RS 38:2212.9, LSA-RS 38:2212.10, LSA-RS 38:2224, and Sec 2-923.1 of the Jefferson Parish Code of Ordinances. For bidding purposes, all bidders must submit with bid submission COMPLETED, SIGNED and PROPERLY NOTARIZED Affidavits, including: Non-Conviction Affidavit, Non-Collusion Affidavit, Campaign Contribution Affidavit, Debt Disclosures Affidavit and E-Verify Affidavit. For the convenience of vendors, all affidavits have been combined into one form entitled PUBLIC WORKS BID AFFIDAVIT. This affidavit must be submitted in its original format, and without material alteration, in order to be compliant and for the bid to be considered responsive. A scanned copy of the completed, signed and properly notarized affidavit may be submitted with the bid, however, the successful bidder must submit the original affidavit in its original format and without material alteration upon contract execution. Failure to comply will result in the bid submission being rejected as non-responsive. The Parish reserves the right to award bid to the next lowest responsive and responsible bidder in this event.
15. **NON PUBLIC WORK BIDS - Completed, Signed and Properly Notarized Affidavits Required** in conformity with the provisions contained in LSA – RS 38:2224 and Sec 2-923.1 of the Jefferson Parish Code of Ordinances. For bidding purposes, all bidders must submit with bid submission COMPLETED, SIGNED and PROPERLY NOTARIZED Affidavits, including: Non-Collusion Affidavit, Debt Disclosures Affidavit and Campaign Contribution Affidavit. For the convenience of vendors, all affidavits have been combined into one form entitled NON PUBLIC WORKS BID AFFIDAVIT. This affidavit must be submitted in its original format, and without material alteration, in order to be compliant and for the bid to be considered responsive. A scanned copy of the completed, signed and properly notarized affidavit may be submitted with the bid, however, the successful bidder must submit the original affidavit in its original format and without material alteration upon contract execution. Failure to comply will result in the bid submission being rejected as non-responsive. The Parish reserves the right to award bid to the next lowest responsive and responsible bidder in this event.
16. The ensuing contract for this bid solicitation may be eligible for FEMA reimbursement and/or Federal funding/reimbursement. As such, the referenced appendix will be applicable accordingly and shall be considered a part of the bid documents. All applicable certifications must be duly completed, signed and submitted with bid submission. Failure to submit applicable certifications with bid submission will result in bid rejection.
17. For this project, the Contractor shall not pay any state or local sales or use taxes on materials and equipment which are affixed and made part of the immovable property of the project or which permanently incorporated in the project (hereinafter referred to as "applicable materials and equipment"). All purchases of applicable materials or equipment shall be made by the contractor on behalf of and as the agent of Jefferson Parish (Owner), a political subdivision of the State of Louisiana. No state and local sales and use taxes are owned on applicable materials and equipment under the provisions of Act 1029 of the 1991 Regular Session – Louisiana Revised Statute 47:301(8)(c). Owner will furnish contractor a certificate form which certifies that Owner is not required to pay such state or local sales and use taxes, and contractor shall furnish a copy of such certificate to all vendors or suppliers of the applicable materials and equipment

It shall be the duty of every parish officer, employee, department, agency, special district, board, and commission; and the duty of every contractor, subcontractor, and licensee of the parish, and the duty of every applicant for certification of eligibility for a parish contract or program, to cooperate with the Inspector General in any investigation, audit, inspection, performance review, or hearing pursuant to JPCO 2-155.10(19). By signing this document, every corporation, partnership, or person contracting with PARISH, whether by cooperative endeavor, intergovernmental agreement, bid, proposal, application or solicitation for a parish contract, and every application for certification of eligibility for a parish contract or program, attests that it understands and will abide by all provisions of JPCO 2-155.10.

DATE: 4/28/2020

Page: 5

BID NO.: 50-00130298

BID FORM
Non Public Works

All Public Work Projects are required to use the Louisiana Uniform Public Work Bid Form

All prices must be held firm unless an escalation provision is requested in this bid. Jefferson Parish will allow one escalation during the term of the contract, which may not exceed the U.S. Bureau of Labor Statistics National Index for all Urban Consumers, unadjusted 12 month figure. The most recently published figure issued at the time an adjustment is requested will be used. A request must be made in writing by the vendor, and the escalation will only be applied to purchases made after the request is made.

Are you requesting an escalation provision?

YES _____ NO X

MAXIMUM ESCALATION PERCENTAGE REQUESTED NA %

INITIAL BID PRICES WILL REMAIN FIRM THROUGH THE DATE OF 1 Year

For the purposes of comparison of bids when an escalation provision is requested, Jefferson Parish will apply the maximum escalation percentage quoted by the bidder to the period to which it is applied in the bid. The initial price and the escalation will be used to calculate the total bid price. It will be assumed, for comparison of prices only, that an equal amount of material or labor is purchased each month throughout the entire contract.

DELIVERY: FOB JEFFERSON PARISH

INDICATE DELIVERY DATE ON EQUIPMENT AND SUPPLIES

4-6 Weeks

LOUISIANA CONTRACTOR'S LICENSE NO.: (if applicable) _____

THIS SECTION MUST BE COMPLETED BY BIDDER:

FIRM NAME: Better Pumps & Solutions, LLC

ADDRESS: 1285 Bayou Paul Lane

CITY, STATE: St. Gabriel, LA

ZIP: 70776

TELEPHONE: (225) 319-7260

FAX: (225) 319-7264

EMAIL ADDRESS: sales@betterpumps.com

In the event that addenda are issued with this bid, bidders MUST acknowledge all addenda on the bid form. Bidder must acknowledge receipt of an addendum on the bid form as indicated. Failure to acknowledge any addendum on the bid form will result in bid rejection.

Acknowledge Receipt of Addenda: NUMBER: 0

NUMBER: _____

NUMBER: _____

NUMBER: _____

TOTAL PRICE OF ALL BID ITEMS: \$ \$70,194.00

AUTHORIZED
SIGNATURE: _____

Joseph Atol IV

Printed Name

TITLE: President

SIGNING INDICATES YOU HAVE READ AND COMPLY WITH THE INSTRUCTIONS AND CONDITIONS.

NOTE: All bids should be returned with the BID NUMBER and BID OPENING DATE indicated on the outside of the envelope submitted to the Purchasing Department.

DATE: 4/28/2020

Page 6

INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00130298

SEALED BID


ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
1	2.00	EA	<p>ONE TIME PURCHASE:</p> <p>0001 - Trash Pump, 6 inch self priming, trailer mount with DOT trailer lights package, driven by an Isuzu model 4LE2T, tier 4 diesel engine, passes 3 inch solids</p> <p>Part no. 6HT-DIST-4LE2T</p> <p>Please Note: One pump is for Eastbank Sewerage Lines Division.</p> <p>One pump is for Westbank Sewerage Lines Division.</p> <p>As per attached specifications</p> <p>*Note: Bidding Alternate*</p> <p>6" Godwin Dri-Prime Trash Pump Model CD150M</p> <p>Specifications attached.</p>	\$35,097.00	\$70,194.00

**RESOLUTION OF THE MEMBERS
OF
BETTER PUMPS & SOLUTIONS, LLC**

A meeting of the Members of Better Pumps & Solutions, LLC was held on the 24 day of August, 2015 at which time the Members waived all requirements of notice of the date, time and place, as well as the purpose of the meeting and after being called to order by Brad Dutruch, Manager, the following resolutions were unanimously adopted:

ON MOTION DULY MADE AND SECONDED, IT WAS UNANIMOUSLY RESOLVED, that Joseph Atol, IV, is hereby appointed as a Manager of Better Pumps & Solutions, LLC, There being no further business before the Members, the meeting was adjourned.

There being no further business before the Members, the meeting was adjourned.


Brad Dutruch, Manager

CERTIFICATE

The above and foregoing is a true and correct copy of the Resolutions that were unanimously adopted by the Members of Better Pumps & Solutions, LLC. at a special meeting of the Members which was held the 24 day of August, 2015 attended by the Members after they had specifically waived all requirements for notice of the meeting and had consented for any business to be brought up before the meeting; and, since the adoption of this Resolution, it has neither been rescinded, vacated, nor set aside and accordingly remains in full force and effect.

Baton Rouge, Louisiana this 24 day of August, 2015.


Brad Dutruch, Manager

Non-Public Works Bid Affidavit Instructions

- **Affidavit is supplied as a courtesy to Affiants, but it is the responsibility of the affiant to insure the affidavit they submit to Jefferson Parish complies, in both form and content, with federal, state and parish laws.**
- **Affidavit must be signed by an authorized representative of the entity or the affidavit will not be accepted.**
- **Affidavit must be notarized or the affidavit will not be accepted.**
- **Notary must sign name, print name, and include bar/notary number, or the affidavit will not be accepted.**
- **Affiant MUST select either A or B when required or the affidavit will not be accepted.**
- **Affiants who select choice A must include an attachment or the affidavit will not be accepted.**
- **If both choice A and B are selected, the affidavit will not be accepted.**
- **Affidavit marked N/A will not be accepted.**
- **It is the responsibility of the Affiant to submit a new affidavit if any additional campaign contributions are made after the affidavit is executed but prior to the time the council acts on the matter.**

Instruction sheet may be omitted when submitting the affidavit

Non-Public Works Bid

AFFIDAVIT

STATE OF Louisiana

PARISH/COUNTY OF East Baton Rouge

BEFORE ME, the undersigned authority, personally came and appeared: Joseph AtoI IV
_____, (Affiant) who after being by me duly sworn, deposed and said that
he/she is the fully authorized President of Better Pumps & Solutions, LLV (Entity),
the party who submitted a bid in response to Bid Number 50-00130298, to the Parish of
Jefferson.

Affiant further said:

Campaign Contribution Disclosures

**(Choose A or B, if option A is indicated please include the required
attachment):**

Choice A _____ Attached hereto is a list of all campaign contributions, including
the date and amount of each contribution, made to current or
former elected officials of the Parish of Jefferson by Entity,
Affiant, and/or officers, directors and owners, including
employees, owning 25% or more of the Entity during the two-year
period immediately preceding the date of this affidavit or the
current term of the elected official, whichever is greater. Further,
Entity, Affiant, and/or Entity Owners have not made any
contributions to or in support of current or former members of the
Jefferson Parish Council or the Jefferson Parish President through
or in the name of another person or legal entity, either directly or
indirectly.

Choice B X there are **NO** campaign contributions made which would require
disclosure under Choice A of this section.

Debt Disclosures

(Choose A or B, if option A is indicated please include the required attachment):

Choice A _____ Attached hereto is a list of all debts owed by the affiant to any elected or appointed official of the Parish of Jefferson, and any and all debts owed by any elected or appointed official of the Parish to the Affiant.


Choice B X There are **NO** debts which would require disclosure under Choice A of this section.

Affiant further said:

That Affiant has employed no person, corporation, firm, association, or other organization, either directly or indirectly, to secure the public contract under which he received payment, other than persons regularly employed by the Affiant whose services in connection with the construction, alteration or demolition of the public building or project or in securing the public contract were in the regular course of their duties for Affiant; and

[The remainder of this page is intentionally left blank.]

That no part of the contract price received by Affiant was paid or will be paid to any person, corporation, firm, association, or other organization for soliciting the contract, other than the payment of their normal compensation to persons regularly employed by the Affiant whose services in connection with the construction, alteration or demolition of the public building or project were in the regular course of their duties for Affiant.



Signature of Affiant

Joseph Atol IV

Printed Name of Affiant

SWORN AND SUBSCRIBED TO BEFORE ME
ON THE 13th DAY OF May, 20 20.



Notary Public


Blane Wilson

Printed Name of Notary

36970

Notary/Bar Roll Number

My commission expires @ Death.





JEFFERSON PARISH

DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR

January 2020

Changes to Jefferson Parish Bidding Information

The Jefferson Parish Purchasing Department would like to make vendors aware of the following changes:

Probable Construction Cost: Per Jefferson Parish Administrative Policy, the probable construction cost is not revealed in the Jefferson Parish Bidding Documents. Jefferson Parish Administrative Policy has changed and a range of the probable construction cost will be stated in the Jefferson Parish bidding document, entitled Important Notice to All Bidders – Bid Requirements. Per Louisiana Public Bid Law, the probable construction cost will be read at the bid opening.

Insurance Requirement: **All bidders** must provide proof of valid insurance in the required amounts as stated in the Standard Insurance Requirements for bidding purposes. Failure to provide the proof of valid insurance in all of the required coverage amounts will result in bid rejection.

GENERAL GOVERNMENT BLDG. – 200 DERBIGNY ST., SUITE 4400, GRETN, LA 70053
OFFICE 504.364.2678

JOSEPH S. YENNI BLDG. – 1221 ELMWOOD PARK BLVD., SUITE 404, JEFFERSON, LA 70123
OFFICE 504.364.2678

EMAIL: PURCHASING@JEFFPARISH.NET WEBSITE: WWW.JEFFPARISH.NET


CD150M Dri-Prime® Pump

WITH ISUZU FINAL TIER 4 DIESEL ENGINE

The Godwin Dri-Prime CD150M pump offers flow rates to 2080 USGPM and has the capability of handling solids up to 3.0" in diameter.

The CD150M is able to automatically prime to 28' of suction lift from dry. Automatic or manual starting/stopping available through integral mounted control panel or optional wireless-remote access.

Indefinite dry-running is no problem due to the unique Godwin liquid bath mechanical seal design. Solids handling, dry-running, and portability make the CD150M the perfect choice for dewatering and bypass applications.



Features and Benefits

- Simple maintenance normally limited to checking fluid levels and filters.
- Dri-Prime (continuously operated Venturi air ejector priming device) requiring no periodic adjustment. Optional compressor clutch available.
- Extensive application flexibility handling sewage, slurries, and liquids with solids up to 3.0" in diameter.
- Dry-running high pressure liquid bath mechanical seal with high abrasion resistant solid silicon carbide faces.
- Close-coupled centrifugal pump with Dri-Prime system coupled to a diesel engine or electric motor.
- All cast iron construction (stainless steel construction option available) with cast steel impeller.
- Also available in a critically silenced unit which reduces noise levels to less than 70 dBA at 30'.
- Standard engine Isuzu 4LE2X (FT4) 62HP.

Specifications

Suction connection	6" 150# ANSI B16.5
Delivery connection	6" 150# ANSI B16.5
Max capacity	2080 USGPM †
Max solids handling	3.0"
Max impeller diameter	11.0"
Max operating temp	176°F*
Max pressure	57 psi
Max suction pressure	58 psi
Max casing pressure	104 psi
Max operating speed	2000 rpm


* Please contact our office for applications in excess of 176°F.

† Larger diameter pipes may be required for maximum flows.

Please contact the factory or office for further details. A typical picture of the pump is shown. All information is approximate and for general guidance only.

godwin 
a xylem brand

Performance Curve



Materials

Pump casing & suction cover	Cast iron BS EN 1561 - 1997
Wearplates	Cast iron BS EN 1561 - 1997
Pump Shaft	Carbon steel BS 970 - 1991 817M40T
Impeller	Cast Steel BS3100 A5 Hardness to 200 HB Brinell
Non-return valve body	Cast iron BS EN 1561 - 1997
Mechanical seal	Silicon carbide face; Viton elastomers; Stainless steel body

Engine option 1

Isuzu 4LE2X (FT4) 62HP Max Engine Rating

Impeller diameter 11.0"

Pump speed 1800 rpm Rated Duty

Suction Lift Table

Total Suction Head (feet)	Total Delivery Head (feet)				
	11	21	32	45	72
Output (USGPM)					
10	1783	1744	1704	1545	1110
15	1684	1585	1486	1288	951
20	1189	1189	1189	1090	693
25	1030	991	911	793	396

Fuel capacity: 60 US Gal

Max Fuel consumption @ 1800 rpm: 2.6 US Gal/hr



Max Fuel consumption @ 1600 rpm: 2.4 US Gal/hr

Weight (Dry): 2,550 lbs

Weight (Wet): 2,980 lbs

Dim.: (L) 119" x (W) 66" x (H) 87"

Performance data provided in tables is based on water tests at sea level and 20°C ambient. All information is approximate and for general guidance only. Please contact the factory or office for further details.



xylem
Let's Solve Water

84 Floodgate Road
Bridgeport, NJ 08014 USA
(856) 467-3636 Fax (856) 467-4841
Email: sales@godwinpumps.com

Reference number : 200GPA0001300
Date of issue : May 16, 2017
Issue : A

www.godwinpumps.com

© 2017 Xylem, Inc. All rights reserved. Godwin is a trademark of Xylem Dewatering Solutions, Inc., a wholly-owned subsidiary of Xylem Inc. Specifications and illustrations are subject to revision without notice. Xylem makes no representation regarding the completeness or accuracy of this information and is not liable for any direct or indirect damages arising from or relating to this information or its use.