

DATE: 2/03/2023

INVITATION TO BID  
THIS IS NOT AN ORDER

Page: 5

BID NO.: 50-00140975

**JEFFERSON PARISH**

PURCHASING DEPARTMENT  
P.O. BOX 9  
GRETNA, LA. 70054-0009  
504-364-2678

VENDOR: 27118 BLANK BID COPY VENDOR

BUYER: BBELLOW

As per LSA-RS 47:301 et seq., all governmental bodies are excluded from payment of sales taxes to any Louisiana taxing body. Quotations shall be based on F.O.B. Agency warehouse or jobsite, anywhere within the Parish as designated by the Purchasing Department.

JEFFERSON PARISH reserves the right to cancel all or any part of an order if not shipped promptly. No charges will be allowed for parking or cartage unless specified in quotation. The order must not be filled at a higher price than quoted. JEFFERSON PARISH reserves the right to cancel at any time and for any reason by issuing a THIRTY (30) day written notice to the contractor.

JEFFERSON PARISH is expecting all products to be new and all work to be done in workman-like manner, according to standard practices. Any deviations or alteration from the specifications must be indicated on the bid form for each item and upon request, product data for same must be submitted by the time specified by the Purchasing Department.

<b>DELIVERY: FOB JEFFERSON PARISH</b>	
INDICATE DELIVERY DATE ON EQUIPMENT AND SUPPLIES	22-24 Weeks
INDICATE STARTING TIME (IN DAYS) FOR CONSTRUCTION WORK	N/A
INDICATE COMPLETION TIME (IN DAYS) FOR CONSTRUCTION WORK	N/A

In the event that addenda are issued with this bid, bidders MUST acknowledge all addenda on the bid form. Bidder must acknowledge receipt of an addendum on the bid form by placing the addendum number as indicated. Failure to acknowledge any addendum on the bid form will result in bid rejection.

Acknowledge Receipt of Addenda: NUMBER: \_\_\_\_\_  
 NUMBER: \_\_\_\_\_  
 NUMBER: \_\_\_\_\_  
 NUMBER: \_\_\_\_\_

LOUISIANA CONTRACTOR'S LICENSE NO.: (if applicable) \_\_\_\_\_

<b>*** ALL BIDDERS MUST COMPLETE SECTION BELOW ***</b>	
<b>FIRM NAME:</b>	Cummins Inc. dba. Cummins Sales and Service
<b>SIGNATURE:</b> (Must be signed here)	<i>Bryan Bealer</i>
<b>PRINT OR TYPE NAME:</b>	Bryan Bealer
<b>ADDRESS:</b>	110 E. Airline Hwy.
<b>CITY, STATE:</b>	Kenner, LA
<b>ZIP:</b>	70062
<b>TELEPHONE:</b>	( 504 ) 465-3435
<b>FAX:</b>	( )
<b>EMAIL ADDRESS:</b>	bryan.bealer@cummins.com

TOTAL PRICE OF ALL BID ITEMS: \$ 9,355.00 FOB DELIVERED

INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00140975

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
1	1.00	EA	<p>ONE TIME PURCHASE OF AN 800 AMP AUTOMATIC TRANSFER SWITCH FOR JEFFERSON PARISH DEPARTMENT OF DRAINAGE</p> <p>0010 AUTOMATIC TRANSFER SWITCH, 800 AMP TO INCLUDE START UP AND TESTING-SERVICE</p> <p>17-18 WEEK LEAD TIME</p> <p>DELIVERY LOCATION:                      SURBURBAN #2 PUMP STATION                      4800 LAKE VILLA DR.                      METAIRIE, LA 70006</p> <p>***PLEASE REVIEW THE ATTACHED BID***                      SPECIFICATIONS</p>	\$ 9,355.00	\$ 9,355.00

# SPECIFICATIONS FOR BID #5000140975

---

## **One Time Purchase for an 800 amp automatic transfer switch**

The intent of this specification is to define the minimum requirements of the Parish of Jefferson for the purchase and delivery of one new 800 amp automatic transfer switch. A bid is a guarantee by the vendor of all specifications being met.

At the request of the Parish and within three working days, any exception to this specification requires the vendor submit a letter attached to the documents listing in detail how it differs from the specifications. Such items may include

- A complete specification and submittal of all major components for the proposed ATS.
- One descriptive brochure showing photographs and/or describing the ATS.

Any bidder not able to supply information shall be considered non-responsive and shall not be accepted.

### **Delivery:**

Freight shall be included in base bid. The ATS shall be delivered to the Suburban pump station warehouse at 4800 Lake Villa Drive, Metairie, La 70006. All deliveries shall be made during operating hours between 7:00 AM and 3:00 PM Monday through Friday. Deliveries will not be accepted during Jefferson parish holidays. Lead time shall be not exceed 20 weeks.

### **Specification:**

Automatic transfer switch shall meet the following specifications:

- OTECD, OTEC Transfer Switch-Electronic Control: 800A/1000A
- OTEC800, Transfer Switch, PowerCommand, 800 Amp
- Listing - UL 1008/CSA Certification
- Application - Utility to Genset
- Cabinet - Type 3R
- Poles - 3 (Solid Neutral)
- Frequency - 60 Hz
- System - 3 Phase, 3 or 4 Wire
- Voltage - 480 Volts AC
- Genset Starting Battery - 24V DC
- PC40 Control
- Auxiliary Relay - Switch in Emergency Position - 24 Volts DC
- Auxiliary Relay - Switch In Normal Position - 24 Volts DC
- One digital copy and one hard copy of the operations and maintenance manual

### **Warranty:**

1. ATS shall be warranted by the manufacturer for defects in materials and workmanship for a period of two years (12 months) from date of shipment.