

DATE: 2/03/2023

INVITATION TO BID
THIS IS NOT AN ORDER

Page: 5

BID NO.: 50-00140975

JEFFERSON PARISH

PURCHASING DEPARTMENT
P.O. BOX 9
GRETNA, LA. 70054-0009
504-364-2678

VENDOR: 27118 BLANK BID COPY VENDOR

BUYER: BBELLOW

As per LSA-RS 47:301 et seq., all governmental bodies are excluded from payment of sales taxes to any Louisiana taxing body. Quotations shall be based on F.O.B. Agency warehouse or jobsite, anywhere within the Parish as designated by the Purchasing Department.

JEFFERSON PARISH reserves the right to cancel all or any part of an order if not shipped promptly. No charges will be allowed for parking or cartage unless specified in quotation. The order must not be filled at a higher price than quoted. JEFFERSON PARISH reserves the right to cancel at any time and for any reason by issuing a THIRTY (30) day written notice to the contractor.

JEFFERSON PARISH is expecting all products to be new and all work to be done in workman-like manner, according to standard practices. Any deviations or alteration from the specifications must be indicated on the bid form for each item and upon request, product data for same must be submitted by the time specified by the Purchasing Department.

DELIVERY: FOB JEFFERSON PARISH	18 - 20 weeks after receipt of final approval drawings
INDICATE DELIVERY DATE ON EQUIPMENT AND SUPPLIES	_____
INDICATE STARTING TIME (IN DAYS) FOR CONSTRUCTION WORK	_____
INDICATE COMPLETION TIME (IN DAYS) FOR CONSTRUCTION WORK	_____

In the event that addenda are issued with this bid, bidders MUST acknowledge all addenda on the bid form. Bidder must acknowledge receipt of an addendum on the bid form by placing the addendum number as indicated. Failure to acknowledge any addendum on the bid form will result in bid rejection.

Acknowledge Receipt of Addenda: NUMBER: _____
NUMBER: _____
NUMBER: _____
NUMBER: _____

LOUISIANA CONTRACTOR'S LICENSE NO.: (if applicable) _____

*** ALL BIDDERS MUST COMPLETE SECTION BELOW ***	
FIRM NAME:	CED dba IC ELECTRIC SUPPLY
SIGNATURE: (Must be signed here)	 TITLE: INSIDE SALES
PRINT OR TYPE NAME:	CHUCK PUIINNO
ADDRESS:	3321 WESTBANK EXPRESSWAY
CITY, STATE:	HARVEY, LA ZIP: 70058
TELEPHONE:	FAX:
(504) 341-4281	(504) 340-3400
EMAIL ADDRESS:	CPUINNO@CED-ICELECTRIC.COM

TOTAL PRICE OF ALL BID ITEMS: \$ 8700.00

INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00140975

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
1	1.00	EA	<p>ONE TIME PURCHASE OF AN 800 AMP AUTOMATIC TRANSFER SWITCH FOR JEFFERSON PARISH DEPARTMENT OF DRAINAGE</p> <p>0010 AUTOMATIC TRANSFER SWITCH, 800 AMP TO INCLUDE START UP AND TESTING-SERVICE</p> <p>17-18 WEEK LEAD TIME</p> <p>DELIVERY LOCATION: SURBURBAN #2 PUMP STATION 4800 LAKE VILLA DR. METAIRIE, LA 70006</p> <p>***PLEASE REVIEW THE ATTACHED BID*** SPECIFICATIONS</p> <p>PLEASE NOTE: QUOTING AN ASCO EQUIVALENT</p> <p>SPECS ATTACHED</p>	\$ <u>\$8700.00</u>	\$ <u>\$8700.00</u>

Product	: Series 300	Catalog Number	: H03ATSA30800NGXF,11BE,44G
Service Voltage / Hz	: 480V/60Hz	Optional Accessories	: 11BE,44G
Bypass Isolation	: Not Applicable	Product Description	: 300 Series, Automatic Open Transition Transfer Switch
No. of Switched Poles	: 3	Neutral Configuration	: Solid [A]
Withstand Rating:	: See WCR table below	No. of Cables & Lug Size	: 4, 1/0 AWG to 600 MCM
Frame = H, Switch Rating = 0800, Series = 300			
Enclosure	: 3R(F)-UL Type 3R Enclosure (See Disclaimer 3)	Service	: Three Phase, 4-wire
Extended Warranty	: Not Included	Markings	:
Shipping to Zip Code	: 70006		\$250.00
Start Up Price to Zip Code	:		Not Included
Estimated Shipment Period:			18 - 20 Week(s) (after final approval and release to Manufacturer)

ACCESSORY DESCRIPTIONS		
#	Accessory Code	Description
1	11BE	Adds the following features to the Group G controller: (1) Serial RS-485 Modbus Communications (2) Multi-Schedule Engine Exerciser (3) a 300 Entry Event Log and (4) a common alarm output function. When applied on 3-phase systems it also enables: (1) 3-Phase Emergency Source VLL sensing (2) Phase Rotation Monitoring (3) Emergency Source VLL Unbalance Monitoring.
2	44G	Strip heater w/ thermostat, wired to load terminals: 208-600 volts

Sub Total - Product Net Price (Excludes Shipping & Handling, Warranty and Start Up)	\$8450.00
Shipping and Handling (Standard Ground) to Zip Code: 70006	\$250.00
Start up Price to zip code :	Not Included
Extended Warranty	Not Included
Estimated Shipment Period	18 - 20 Week(s) (after final approval and release to Manufacturer)

ASCO UL1008 Withstand and Closing Ratings ^{1,2,7}
(RMS Symmetrical Amps)

Frame	Switch Rating (Amps)		300, 4000 & 7000 Series				4000 & 7000 Series			7000 Series											
			Current Limiting Fuses				Specific Breaker			Time Based			Short Time Ratings ³ (sec)								
	Transfer Switches	Bypass Switches	480V Max.	600V Max.	Max Size, A	Class	240V Max.	480V Max.	600V Max.	Time (sec)	240V Max.	480V Max.	600V Max.	480V Max.			600V Max.				
														.13	.2	.3	.5	.1	.13	.3	.5
D	30	-	100kA	-	300	J	22kA	22kA	10kA	0.025	10kA	10kA	10kA	-	-	-	-	-	-	-	-
D	70, 100	-	200kA	35kA	200	J	150kA	85kA	25kA	0.025	10kA	10kA	10kA	-	-	-	-	-	-	-	-
D	150	-	35kA	35kA	200	RK1	150kA	85kA	25kA	0.025	10kA	10kA	10kA	-	-	-	-	-	-	-	-
D	200	-	200kA	35kA	200	J	200kA	85kA	14kA	0.025	10kA	10kA	10kA	-	-	-	-	-	-	-	-
D	230	-	200kA	35kA	200	J	200kA	85kA	14kA	0.025	10kA	10kA	10kA	-	-	-	-	-	-	-	-
E	260, 400	-	200kA	-	600	J	65kA	42kA	22kA	0.05	35kA	35kA	22kA	-	-	-	-	-	-	-	-
J	150, 200, 260	150, 200, 230, 260	200kA	200kA	600	J	200kA	200kA	42kA	0.05	65kA	42kA ⁵	35kA	7.5kA	-	-	-	-	-	-	-
J	400	400	200kA	200kA	800	L	65kA	50kA	42kA	0.05	65kA	42kA ⁵	35kA	7.5kA	-	-	-	-	-	-	-
J	600	600	200kA	200kA	800	L	65kA	85kA	42kA	0.05	65kA	42kA ⁵	35kA	7.5kA ⁹	-	-	-	-	-	-	-
H ⁸	600	600	200kA	200kA	1600	L	65kA	150kA	65kA	0.05	50kA	50kA	50kA	36kA	-	-	36kA	-	-	-	-
P ⁸	600	600	200kA	200kA	1600	L	65kA	150kA	65kA	0.05	50kA	50kA	50kA	36kA	30kA	36kA	-	-	-	-	-
P ⁸	800	800 - 1200	200kA	200kA	1600	L	65kA	150kA	65kA	0.05	50kA	50kA	50kA	36kA	30kA	36kA	-	-	-	-	-
H	800 - 1200	800 - 1200	200kA	200kA	1600 ⁴	L	65kA	150kA	65kA	0.05	50kA	50kA	50kA	36kA	-	-	36kA	-	-	-	-
Q ⁸	600-1600	600-1600	200kA	200kA	2000	L	65kA	65kA	65kA	0.05	65kA	65kA	65kA	50kA	-	-	50kA	-	-	-	-
S ⁸	800 - 1200	800 - 1200	200kA	200kA	2500	L	100kA	100kA	65kA	0.05	100kA	100kA	65kA	65kA	-	-	65kA	-	-	-	-
G ⁸	1000 - 1200	1000 - 1200	200kA	200kA	2000	L	85kA	85kA	85kA	0.05	85kA	85kA	85kA	-	-	-	-	-	-	-	-
G	1600 - 2000 (Front Connected TS Only)		200kA	200kA	2500	L	85kA	85kA	85kA	0.05	85kA	85kA	85kA	42kA	36kA	-	-	-	-	-	-
G ⁸	1600 - 2000	1600 - 2000	200kA	200kA	3000	L	200kA	200kA	100kA	0.05	100kA	100kA	100kA	42kA	36kA	42kA	36kA	42kA	-	-	-
S ⁸	1600 - 2000	1600 - 2000	200kA	200kA	2500	L	100kA	100kA	85kA	0.05	100kA	100kA	85kA	85kA	65kA	85kA	65kA	85kA	65kA	65kA	65kA
G	2600 - 3000	2600 - 3000	200kA	200kA	4000	L	125kA ⁹	125kA ⁹	100kA	0.05	100kA	100kA	100kA	42kA	36kA	42kA	36kA	42kA	-	-	-
G ⁸	3200	-	200kA	-	4000	L	100kA	100kA	-	0.05	100kA	100kA	-	-	-	-	-	-	-	-	-
G	4000	4000	200kA	200kA	5000	L	100kA	100kA	100kA	0.05	100kA	100kA	100kA	85kA	65kA	85kA	65kA	85kA	65kA	65kA	65kA
U ⁸	2600 - 4000	2600 - 4000	200kA	200kA	5000	L	125kA	125kA	125kA	0.05	125kA	125kA	125kA	100kA	-	-	100kA	-	-	-	-

- Notes:
- 1) All WCR values indicated are tested in accordance with the requirements of UL 1008, 7th Edition. See ASCO Pub. 1128 for more WCR information
 - 2) Application requirements may permit higher WCR for certain switch sizes
 - 3) Short Time ratings are provided for applications involving circuit breakers that utilize trip delay settings for system selective coordination
 - 4) Max fuse rating is 1200A on front connected H frame switches
 - 5) Switches utilizing overlapping neutral (code "C") have 35kA, 0.050 Sec time based rating at 480V Max
 - 6) Rating shown is for Bypass switches only, Transfer Switch rating is 100kA
 - 7) See ASCO for Service Entrance Switch ratings
 - 8) These frames are only available on the 7000 Series product
 - 9) Short Time Rating applies to 600A Bypass switch only, the 600A Transfer Switch does not have a Short Time Rating