

DATE: 7/18/2018
BID NO.: 50-00123637

INVITATION TO BID
THIS IS NOT AN ORDER

Page: 1

JEFFERSON PARISH

PURCHASING DEPARTMENT
P.O. BOX 9
GRETNA, LA. 70054-0009
504-364-2678

BUYER: DREAMEY@jeffparish.net

BIDS WILL BE RECEIVED IN THE WEST BANK PURCHASING DEPT, SUITE 4400, JEFFERSON PARISH GENERAL GOVERNMENT BUILDING, 200 DERBIGNY STREET, GRETNA, LA 70053 UNTIL 2:00 PM, 8/02/2018 AND PUBLICLY OPENED THEREAFTER.

For convenience, bidders may also submit bids in the East Bank Purchasing Department, Suite 404, Jefferson Parish Joseph S. Yenni Building, 1221 Elmwood Park Blvd., Jefferson LA 70123. However, if submitting bids on the day of bid opening, bidders must submit at the West Bank location only. All bids will be publicly opened at the West Bank location.

At no charge, bidders may also submit via Jefferson Parish's electronic procurement page by visiting www.jeffparishbids.net to register for this free site. Additional instructions are included in the text box highlighting electronic procurement.

LATE BIDS WILL NOT BE ACCEPTED

Unless submitting via online (see Page 3), each bid must be submitted in a sealed envelope bearing on the outside; the name of the Bidder, his address, and the name of the project for which the bid is submitted and the bid number.

NOTE: ONLY BIDS WRITTEN IN INK OR TYPEWRITTEN, AND PROPERLY SIGNED BY A MEMBER OF THE FIRM OR AUTHORIZED REPRESENTATIVE, WILL BE ACCEPTED. PENCIL AND/OR PHOTOSTATIC FIGURES OR SIGNATURES SHALL RESULT IN BID REJECTION.

INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS

THE FOLLOWING INSTRUCTIONS APPLY TO ALL BIDS

All bids submitted are subject to these instructions and general conditions and any special conditions and specifications contained herein, all of which are made part of this bid proposal reference. By submitting a bid, vendor agrees to comply with all provisions of Louisiana Law as well be in compliance with the Jefferson Parish Code of Ordinances, Louisiana Code of Ethics, applicable Jefferson Parish ethical standards and Jefferson Parish Resolution No. 113646 and/or Resolution No. 113647.

All vendors submitting bids should register as a Jefferson Parish vendor if not already yet registered. Registration forms may be downloaded from <http://purchasing.jeffparish.net> and by clicking on Vendor Information. Current W-9 forms with respective Tax Identification numbers and vendor applications may be submitted at any time; however, if your company is not registered and/or a current W-9 form is not on file, vendor registration is mandatory. Further, a current W-9 form and respective Tax Identification number must be supplied upon contract execution, should you be awarded a contract and/or issued purchase order. Failure to do so may result in delay of payment.

All quotations shall be based on F.O.B. Agency warehouse or job site, anywhere within the Parish as designated by the Purchasing Department. This provision does not apply to public works projects

JEFFERSON PARISH requires all products to be new (current) and all work must be performed according to standard practices for the project. Unless otherwise specified, no aftermarket parts will be accepted. Unless otherwise specified, all workmanship and materials must have at least one (1) year guaranty, in writing, from the date of delivery and/or acceptance of the project. Any deviations or alterations from the specifications must be indicated and/or supporting documentation supplied with bid submission.

Bidders should submit all questions in writing via email to the buyer's email address as indicated above, no later than Five (5) working days prior to the bid opening. Bid numbers should be mentioned in all requests. If submitting online, vendors may send questions via the E-Procurement site no later than Five (5) working days prior to the bid opening.

If this bid requires a pre-bid conference (see Additional Requirements section), bidders are advised that such conference will be held to allow bidders the opportunity to identify any discrepancies in the bid specifications and seek further clarification regarding instructions. The Purchasing Department will issue a written response to bidders' questions in the form of an Addendum. Please note that all official communication will be expressed in the form of an addendum.

All formal Addenda require written acknowledgement on the bid form by the bidder. Failure to acknowledge an Addendum on the bid form shall cause the bid to be rejected. JEFFERSON PARISH reserves the right to award bid to next lowest responsive and responsible bidder in this event.

The purpose and intention of this invitation to bid is to afford all suppliers an equal opportunity to bid on all construction, maintenance, repair, operating supplies and/or equipment listed in this bid proposal. JEFFERSON PARISH WILL ACCEPT ONE BID ONLY FROM EACH VENDOR. Items bid must meet specifications.

Visit our website at [HTTP://PURCHASING.JEFFPARISH.NET](http://PURCHASING.JEFFPARISH.NET)

DATE: 7/18/2018

BID NO.: 50-00123637

Page: 2

JEFFERSON PARISH will accept one price for each item unless otherwise indicated. Two or more prices for one item will result in bid rejection. Bidders are required to complete, sign and return the bid form and/or complete and return the associated line item pricing forms as indicated. Vendors must not alter the bid forms. Doing so will cause the bid to be rejected.

A corporate resolution or written evidence of the individual signing the bid having such authority must be submitted with the bid. Failure to comply will cause bid to be rejected. For corporate entities, such written evidence may be a printout of the Louisiana Secretary of State's website listing the signatory as an officer. Such printout shall be included with the bid submission. Bids submitted by Owners or Sole Proprietorships must include certification that he or she owns the entity for which the bid is signed. This documentation must be submitted with the bid. Failure to do so will result in bid rejection.

NOTE: A sample corporate resolution can be downloaded from our website <http://purchasing.jeffparish.net> or you may provide your own document. A sample certification of sole proprietorship can also be downloaded from our website <http://purchasing.jeffparish.net> or you may provide your own document.

INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS

A. AWARD OF CONTRACT: JEFFERSON PARISH reserves the right to award contracts or place orders on a lump sum or individual item basis, or such combination, as shall in its judgment be in the best interest of JEFFERSON PARISH. Every contract or order shall be awarded to the LOWEST RESPONSIVE and RESPONSIBLE BIDDER, taking into consideration the CONFORMITY WITH THE SPECIFICATIONS and the DELIVERY AND/OR COMPLETION DATE. SPLIT AWARDS MADE TO SEVERAL VENDORS WILL ONLY BE GRANTED TO THOSE DEEMED RESPONSIVE AND RESPONSIBLE.

All bid prices shall remain valid for 45 days. Jefferson Parish and the lowest responsive and responsible bidder(s) by mutual written consent may mutually agree to extend the deadline for award by one (1) or more extensions of thirty (30) calendar days.

PROTESTS: Only those vendors that submitted a bid in response to this solicitation may submit a protest in writing to the Director of the Purchasing within 48 hours of bid opening. The Purchasing Director will review it in connection with the Parish Attorney's Office which will then respond in writing as soon as possible.

PREFERENCE: Unless federal funding is directly spent by Jefferson Parish for this purchase, preference is hereby given to materials, supplies, and provisions produced, manufactured or grown in Louisiana, quality being equal to articles offered by competitors outside the state. "LSA - R.S. 38:2251-2261"

B. USE OF BRAND NAMES AND STOCK NUMBERS: Where brand names and stock numbers are specified, it is for the purpose of establishing certain minimum standards of quality. Bids may be submitted for products of equal quality, provided brand names and stock numbers are specified. Complete product data may be required prior to award.

C. CANCELLATION OF CONTRACT: JEFFERSON PARISH reserves the right to cancel all or any part if not shipped promptly. No charges will be allowed for parking or cartage unless specified in quotation. The order must not be filled at a higher price than quoted. JEFFERSON PARISH reserves the right to cancel any contract at anytime and for any reason by issuing a THIRTY (30) day written notice to the contractor.

For good cause and as consideration for executing a contract with Jefferson Parish, vendor conveys, sells, assigns and transfers to Jefferson Parish or its assigns all rights, title and interest in and to all causes of action it may now or hereafter acquire under the antitrust laws of the United States and the State of Louisiana, relating to the particular good or services purchased or acquired by Jefferson Parish.

D. PRICES: Jefferson Parish is exempt from paying sales tax under LSA-R.S. 47:301 (8)(c). All prices for purchases by Jefferson Parish of supplies and materials shall be quoted in the unit of measure specified and unless otherwise specified, shall be exclusive of state and Parish taxes. The price quoted for work shall be stated in figures. In the event there is a difference in unit prices and totals, the unit price shall prevail.

Quantities listed are for bidding purposes only. Actual requirements may be more or less than quantities listed.

Bidders are not to exclude from participation in, deny the benefits of, or subject to discrimination under any program or activity, any person in the United States on the grounds of race, color, national origin, or sex; nor discriminate on the basis of age under the Age Discrimination Act of 1975, or with respect to an otherwise qualified handicapped individual as provided in Section 504 of the Rehabilitation Act of 1973, or on the basis of religion, except that any exemption from such prohibition against discrimination on the basis of religion as provided in the Civil Rights Act of 1964, or Title VI and VII of the Act of April 11, 1968, shall also apply. This assurance includes compliance with the administrative requirements of the Revenue Sharing final handicapped discrimination provisions contained in Section 51.55 (c), (d), (e), and (k)(5) of the Regulations. New construction or renovation projects must comply with Section 504 of the 1973 Rehabilitation Act, as amended, in accordance with the American National Standard Institute's specifications (ANSI A17.1-1961).

Jefferson Parish and its partners as the recipients of federal funds are fully committed to awarding a contract(s) to firm(s) that will provide high quality services and that are dedicated to diversity and to containing costs. Thus, Jefferson Parish strongly encourages the involvement of minority and/or woman-owned business enterprises (DBE's, including MBE's, WBE's and SBE's) to stimulate participation in procurement and assistance programs.

INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS

Advertised bids will be tabulated and a copy of the tabulation will be forwarded to each responding bidder.

IN ACCORDANCE WITH STATE REGULATIONS JEFFERSON PARISH OFFERS ELECTRONIC PROCUREMENT TO ALL VENDORS

This electronic procurement system allows vendors the convenience of reviewing and submitting bids online. This is a secure site and authorized personnel have limited read access only. Bidders are encouraged to submit electronically using this free service; while the website accepts various file types, one single PDF file containing all appropriate and required bid documents is preferred. Bidders submitting uploaded images of bid responses are solely responsible for clarity. If uploaded images/documents are not legible, then bidder's submission will be rejected. Please note all requirements contained in this bid package for electronic bid submission.

Please visit our E-Procurement Page at www.jeffparishbids.net to register and view Jefferson Parish solicitations. For more information, please visit the Purchasing Department page at <http://purchasing.jeffparish.net>.

The general specifications for construction projects and the purchase of materials, services and/or supplies are those adopted by the JEFFERSON PARISH Council by Resolution No. 113646 or 113647 dated 12/09/09. The general conditions adopted by this resolution shall be considered as much a part of this document as if they were written wholly herein. A copy may be obtained from the Office of the Parish Clerk, Suite 6700, Jefferson Parish General Government Building, 200 Derbigny Street, Gretna, LA 70053. You may also obtain a copy by visiting the Purchasing Department webpage at <http://purchasing.jeffparish.net> and clicking on Online Forms.

ADDITIONAL REQUIREMENTS FOR THIS BID

PLEASE MATCH THE NUMBERS PRINTED IN THIS BOX WITH THE
CORRESPONDING INSTRUCTIONS BELOW.

13,15

1. All bidders must attend the MANDATORY pre-bid conference and will be required to sign in and out as evidence of attendance. In accordance with LSA R.S. 38:2212(l), all prospective bidders shall be present at the beginning of the MANDATORY pre-bid conference and shall remain in attendance for the duration of the conference. Any prospective bidder who fails to attend the conference or remain for the duration shall be prohibited from submitting a bid for the project.
2. Attendance to this pre-bid conference is optional. However, failure to attend the pre-bid conference shall not relieve the bidder of responsibility for information discussed at the conference. Furthermore, failure to attend the pre-bid conference and inspection does not relieve the successful bidder from the necessity of furnishing materials or performing any work that may be required to complete the work in accordance with the specification with no additional cost to the owner.
3. Contractor must hold current applicable JEFFERSON PARISH licenses with the Department of Inspection and Code Enforcement. Contractor shall obtain any and all permits required by the JEFFERSON PARISH Department of Inspection and Code Enforcement. The contractor shall be responsible for the payment of these permits. All permits must be obtained prior to the start of the project. Contractor must also hold any and all applicable Federal and State licenses. Contractor shall be responsible for the payment of these permits and shall obtain them prior to the start of the project.
4. A LA State Contractor's License will be required in accordance with LSA R.S. 37-2150 et. seq. and such license number will be shown on the outside of the bid envelope. Failure to comply will cause the bid to be rejected. Additionally if submitting the bid electronically, then the license number must be entered in the appropriate field in the Electronic Procurement system. Failure to comply will cause the bid to be rejected.
5. It is the bidder's responsibility to visit the job site and evaluate the job before submitting a bid.
6. Job site must be clean and free of all litter and debris daily and upon completion of the contract. Passageways must be kept clean and free of material, equipment, and debris at all times. Flammable material must be removed from the job site daily because storage will not be permitted on the premises. Precautions must be exercised at all times to safeguard the welfare of JEFFERSON PARISH and the general public.

INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS

7. **PUBLIC WORKS BIDS:** All awards for public works in excess of \$5,000.00 will be reduced to a formal contract which shall be recorded at the contractor's expense with the Clerk of Court and Ex-Officio Recorder of Mortgages for the Parish of Jefferson. A price list of recordation costs may be obtained from the Clerk of Court and Ex-Officio Recorder of Mortgages for the Parish of Jefferson. All awards in excess of \$25,000.00 will require both a performance and a payment bond. Unless otherwise stated in the bid specifications, the performance bond requirements shall be 100% of the contract price. Unless otherwise state in the bid specifications, the payment bond requirements shall be 100% of the contract price. Both bonds shall be supplied at the signing of the contract.
8. **NON-PUBLIC WORKS BIDS:** A performance bond will be required for this bid. The amount of the bond will be 100% of the contract price unless otherwise indicated in the specifications. The performance bond shall be supplied at the signing of the contract.
9. **NON-PUBLIC WORKS BIDS:** A payment bond will be required for this bid. The amount of the bond will be 100% of the contract price unless otherwise indicated in the specifications. The payment bond shall be supplied at the signing of the contract.
10. All bidders must comply with the requirements stated in the attached "Standard Insurance Requirements" sheet attached to this bid solicitation. Prior to contract executions/purchase order issuance, the successful bidder will be required to provide final insurance certificates which shall name Jefferson Parish as an additional insured in accordance with the instructions in the aforementioned "Standard Insurance Requirements" sheet.
11. A bid bond will be required with bid submission in the amount of 5% of the total bid, unless otherwise stated in the bid specifications. Acceptable forms shall be limited to cashier's check, certified check, or surety bid bond. All sureties must be in original format (no copies) If submitting a bid online, vendors must submit an electronic bid bond through the respective online clearinghouse bond management system(s) as indicated in the electronic bid solicitation on Central Auction House. No scanned paper copies of any bid bond will be accepted as part of the electronic bid submission.
12. This is a requirements contract to be provided on an as needed basis. JEFFERSON PARISH makes no representations on warranties with regard to minimum guaranteed quantities unless otherwise stated in the bid specifications.
13. Freight charges should be included in total cost when quoting. If not quoted FOB DELIVERED, freight must be quoted as a separate item. Bid may be rejected if not quoted FOB DELIVERED or if freight charges are not indicated on bid form.
14. **PUBLIC WORKS BIDS - Completed, Signed and Properly Notarized Affidavits Required;** This applies to all solicitations for construction, alteration or demolition of public buildings or projects, in conformity with the provisions contained in LSA-RS 38:2212.9, LSA-RS 38:2212.10, LSA-RS 38:2224, and Sec 2-923.1 of the Jefferson Parish Code of Ordinances. For bidding purposes, all bidders must submit with bid submission COMPLETED, SIGNED and PROPERLY NOTARIZED Affidavits, including: Non-Conviction Affidavit, Non-Collusion Affidavit, Campaign Contribution Affidavit, Debt Disclosures Affidavit and E-Verify Affidavit. For the convenience of vendors, all affidavits have been combined into one form entitled PUBLIC WORKS BID AFFIDAVIT. This affidavit must be submitted in its original format, and without material alteration, in order to be compliant and for the bid to be considered responsive. A scanned copy of the completed, signed and properly notarized affidavit may be submitted with the bid, however, the successful bidder must submit the original affidavit in its original format and without material alteration upon contract execution. Failure to comply will result in the bid submission being rejected as non-responsive. The Parish reserves the right to award bid to the next lowest responsive and responsible bidder in this event.
15. **NON PUBLIC WORK BIDS - Completed, Signed and Properly Notarized Affidavits Required** in conformity with the provisions contained in LSA – RS 38:2224 and Sec 2-923.1 of the Jefferson Parish Code of Ordinances. For bidding purposes, all bidders must submit with bid submission COMPLETED, SIGNED and PROPERLY NOTARIZED Affidavits, including: Non-Collusion Affidavit, Debt Disclosures Affidavit and Campaign Contribution Affidavit. For the convenience of vendors, all affidavits have been combined into one form entitled NON PUBLIC WORKS BID AFFIDAVIT. This affidavit must be submitted in its original format, and without material alteration, in order to be compliant and for the bid to be considered responsive. A scanned copy of the completed, signed and properly notarized affidavit may be submitted with the bid, however, the successful bidder must submit the original affidavit in its original format and without material alteration upon contract execution. Failure to comply will result in the bid submission being rejected as non-responsive. The Parish reserves the right to award bid to the next lowest responsive and responsible bidder in this event.
16. The ensuing contract for this bid solicitation may be eligible for FEMA reimbursement and/or Federal funding/reimbursement. As such, the referenced appendix will be applicable accordingly and shall be considered a part of the bid documents. All applicable certifications must be duly completed, signed and submitted with bid submission. Failure to submit applicable certifications with bid submission will result in bid rejection.
17. For this project, the Contractor shall not pay any state or local sales or use taxes on materials and equipment which are affixed and made part of the immovable property of the project or which permanently incorporated in the project (hereinafter referred to as "applicable materials and equipment"). All purchases of applicable materials or equipment shall be made by the contractor on behalf of and as the agent of Jefferson Parish (Owner), a political subdivision of the State of Louisiana. No state and local sales and use taxes are owned on applicable materials and equipment under the provisions of Act 1029 of the 1991 Regular Session – Louisiana Revised Statute 47:301(8)(c). Owner will furnish contractor a certificate form which certifies that Owner is not required to pay such state or local sales and use taxes, and contractor shall furnish a copy of such certificate to all vendors or suppliers of the applicable materials and equipment

It shall be the duty of every parish officer, employee, department, agency, special district, board, and commission; and the duty of every contractor, subcontractor, and licensee of the parish, and the duty of every applicant for certification of eligibility for a parish contract or program, to cooperate with the Inspector General in any investigation, audit, inspection, performance review, or hearing pursuant to Jefferson Parish Code of Ordinances Section 2-155.10(19). By submitting a bid, vendor acknowledges this and will abide by all provisions of the referenced Jefferson Parish Code of Ordinances.

DATE: 7/18/2018

Page: 5

BID NO.: 50-00123637

BID FORM
Non Public Works

All Public Work Projects are required to use the Louisiana Uniform Public Work Bid Form

All prices must be held firm unless an escalation provision is requested in this bid. Jefferson Parish will allow one escalation during the term of the contract, which may not exceed the U.S. Bureau of Labor Statistics National Index for all Urban Consumers, unadjusted 12 month figure. The most recently published figure issued at the time an adjustment is requested will be used. A request must be made in writing by the vendor, and the escalation will only be applied to purchases made after the request is made.

Are you requesting an escalation provision?

YES _____ NO X

MAXIMUM ESCALATION PERCENTAGE REQUESTED _____%

INITIAL BID PRICES WILL REMAIN FIRM THROUGH THE DATE OF 11/02/18.

For the purposes of comparison of bids when an escalation provision is requested, Jefferson Parish will apply the maximum escalation percentage quoted by the bidder to the period to which it is applied in the bid. The initial price and the escalation will be used to calculate the total bid price. It will be assumed, for comparison of prices only, that an equal amount of material or labor is purchased each month throughout the entire contract.

DELIVERY: FOB JEFFERSON PARISH

INDICATE DELIVERY DATE ON EQUIPMENT AND SUPPLIES

4 - 6 Weeks

LOUISIANA CONTRACTOR'S LICENSE NO.: (if applicable)

N/A

THIS SECTION MUST BE COMPLETED BY BIDDER:

FIRM NAME: Fluid Process & Pumps, LLC

ADDRESS: P.O. Box 10608

CITY, STATE: New Orleans, LA

ZIP: 70181

TELEPHONE: (504) 733-1330

FAX: (504) 736-9348

EMAIL ADDRESS: bb@fluidprocess.net

In the event that addenda are issued with this bid, bidders MUST acknowledge all addenda on the bid form. Bidder must acknowledge receipt of an addendum on the bid form as indicated. Failure to acknowledge any addendum on the bid form will result in bid rejection.

Acknowledge Receipt of Addenda: NUMBER: Addendum No. 1

NUMBER: _____

NUMBER: _____

NUMBER: _____

TOTAL PRICE OF ALL BID ITEMS: \$ 87,150.00

AUTHORIZED

SIGNATURE: Carl A. Deroche, Jr.

Carl A. Deroche, Jr.

Printed Name

TITLE: President

SIGNING INDICATES YOU HAVE READ AND COMPLY WITH THE INSTRUCTIONS AND CONDITIONS.

NOTE: All bids should be returned with the BID NUMBER and BID OPENING DATE indicated on the outside of the envelope submitted to the Purchasing Department.

DATE: 7/18/2018

Page 6

INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00123637

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
1	3.00	EA	<p>ONE TIME PURCHASE OF 8 INCH SUBMERSIBLE NON-CLOG SEWER PUMPS</p> <p>0001 Hydromatic S8LXP4000FB pump with 50 foot cords, 40HP, 460/3/60, 1150 RPM explosion-proof premium efficient submersible non clog sewage pump and motor with 8 inch discharge to match the existing pumps dimensions and hydraulics</p> <p>For Sewer Lift Station D8-6; Page & Longfellow</p>	\$29,050.00	\$87,150.00

**CONSENT AND CERTIFICATE OF AUTHORITY
OF
FLUID PROCESS & PUMPS, L.L.C.**

The undersigned constitutes the sole member and manager of **FLUID PROCESS & PUMPS, L.L.C.** (the "Company").

In such capacity, the undersigned are authorized to and do hereby certify to the following matters pertaining to the Company:


A. The Company is existing and operating pursuant to Articles of Organization of the Company which were filed with the Secretary of State of Louisiana on April 5, 2010, and they have not been amended (the "Articles of Organization"). The Company has no written operating agreement.

B. **Carl A. Deroche, Jr.** is the sole member and manager of the Company, and he does hereby appoint and designate himself, Carl A. Deroche, Jr. ("Manager") to have the full power and authority to act in the name of and on behalf of the Company to cause the Company to take the following actions:

- (1) to enter into a contract with **Jefferson Parish Government for 8" Submersible Non-clog Sewer pumps**, on such terms and conditions contained therein, and execute any and all other documents that may be required or that Manager deems in his sole discretion necessary, advisable or appropriate to effectuate the matter(s) described herein;
- (2) to acquire, whether by sale, donation, exchange, lease or any other manner, any property whether movable or immovable, whether corporeal or incorporeal, or any interests therein, including leasehold or subleasehold interests, servitudes, or rights of use, as Manager may in his sole discretion consider appropriate, all for such price and upon such terms and conditions as the Manager may in his sole discretion consider appropriate;
- (3) to enter into any and all manner of agreements and contracts in connection with the above matter(s), all upon such terms and conditions as the Manager may in his sole discretion consider appropriate; and
- (4) generally to do any and all other acts that the said Manager may, in his sole discretion, consider appropriate in order to effectuate any of the matter(s) described herein, all upon such terms and conditions as the said Manager may in his sole discretion consider appropriate, and all pursuant to such documents and instruments, containing such clauses and provisions, as the said Manager may in his sole discretion consider appropriate.

Carl A. Deroche, Jr., in his capacity as the sole member and manager and certifying official of the Company, pursuant to La.-R.S. 1305(c)(5), executes this Certificate for the purpose of certifying the authority of the Manager/Agent as above described.

This Certificate is effective as of the date of execution hereof.

By: 

Carl A. Deroche, Jr.
Sole Member and Manager

Date: 07/26/18

Non-Public Works Bid Affidavit Instructions

- Affidavit is supplied as a courtesy to Affiants, but it is the responsibility of the affiant to insure the affidavit they submit to Jefferson Parish complies, in both form and content, with federal, state and parish laws.
- Affidavit must be signed by an authorized representative of the entity or the affidavit will not be accepted.
- Affidavit must be notarized or the affidavit will not be accepted.
- Notary must sign name, print name, and include bar/notary number, or the affidavit will not be accepted.
- Affiant **MUST** select either A or B when required or the affidavit will not be accepted.
- Affiants who select choice A must include an attachment or the affidavit will not be accepted.
- If both choice A and B are selected, the affidavit will not be accepted.
- Affidavit marked N/A will not be accepted.
- It is the responsibility of the Affiant to submit a new affidavit if any additional campaign contributions are made after the affidavit is executed but prior to the time the council acts on the matter.

Instruction sheet may be omitted when submitting the affidavit

Non-Public Works Bid

AFFIDAVIT

STATE OF Louisiana

PARISH/~~COUNTY~~ OF Jefferson

BEFORE ME, the undersigned authority, personally came and appeared: _____

Carl A. Deroche, Jr, (Affiant) who after being by me duly sworn, deposed and said that he/she is the fully authorized President of Fluid Process & Pumps(Entity), the party who submitted a bid in response to Bid Number 50-00123637, to the Parish of Jefferson.

Affiant further said:

Campaign Contribution Disclosures

(Choose A or B, if option A is indicated please include the required attachment):

Choice A X

Attached hereto is a list of all campaign contributions, including the date and amount of each contribution, made to current or former elected officials of the Parish of Jefferson by Entity, Affiant, and/or officers, directors and owners, including employees, owning 25% or more of the Entity during the two-year period immediately preceding the date of this affidavit or the current term of the elected official, whichever is greater. Further, Entity, Affiant, and/or Entity Owners have not made any contributions to or in support of current or former members of the Jefferson Parish Council or the Jefferson Parish President through or in the name of another person or legal entity, either directly or indirectly.

Choice B _____

there are **NO** campaign contributions made which would require disclosure under Choice A of this section.

Debt Disclosures

(Choose A or B, if option A is indicated please include the required attachment):

Choice A _____ Attached hereto is a list of all debts owed by the affiant to any elected or appointed official of the Parish of Jefferson, and any and all debts owed by any elected or appointed official of the Parish to the Affiant.

Choice B X _____ There are **NO** debts which would require disclosure under Choice A of this section.

Affiant further said:

That Affiant has employed no person, corporation, firm, association, or other organization, either directly or indirectly, to secure the public contract under which he received payment, other than persons regularly employed by the Affiant whose services in connection with the construction, alteration or demolition of the public building or project or in securing the public contract were in the regular course of their duties for Affiant; and

[The remainder of this page is intentionally left blank.]

That no part of the contract price received by Affiant was paid or will be paid to any person, corporation, firm, association, or other organization for soliciting the contract, other than the payment of their normal compensation to persons regularly employed by the Affiant whose services in connection with the construction, alteration or demolition of the public building or project were in the regular course of their duties for Affiant.



Signature of Affiant

Carl A. Deroche, Jr.
Printed Name of Affiant

SWORN AND SUBSCRIBED TO BEFORE ME

ON THE 26th DAY OF July, 2018.



Notary Public

Alan Emerman
Printed Name of Notary

ID #36648
Notary/Bar Roll Number

My commission expires For Life.

ATTACHMENT:

Campaign Contribution Disclosures:

Payee: Elton Lagasse - Campaign Fund
 Check #: 11656
 Date: 4/28/15
 Amount: \$1,000.00

Payee: Elton Lagasse - Campaign Fund
 Check #: 12194
 Date: 7/7/15
 Amount: \$1,500.00

Payee: Paul Johnston - Campaign Fund
 Check #: 12355
 Date: 8/3/15
 Amount: \$1,000.00

Payee: Michael S. Yenni - Campaign Fund
 Check #: 12393
 Date: 8/7/15
 Amount: \$2,500.00

Payee: Michael S. Yenni - Campaign Fund
 Check #: 13804
 Date: 4/19/16
 Amount: \$1,500.00

Payee: Michael S. Yenni - Campaign Fund
 Check #: 15607
 Date: 3/24/17
 Amount: \$1,000.00

Payee: Danny Martiny Campaign Fund
 Check #: 15823
 Date: 5/8/17
 Amount: \$1,000.00

Payee: Dominick Impastato Campaign Fund
 Check #: 16498
 Date: 9/12/17
 Amount: \$2,500.00

Payee: Committee to Elect Joseph Lopinto Sheriff
 Check #: 17659
 Date: 2/6/18
 Amount: \$5,000.00

Payee: Michael S. Yenni - Campaign Fund
 Check #: 18153
 Date: 5/9/18
 Amount: \$1,500.00

Louisiana Secretary of State

R. Kyle Ardoin

SEARCH FOR LOUISIANA NOTARIES

A practicing notary in a parish may notarize in reciprocal parishes without additional bonding or examination.

You can also download information about all notaries on file. For more information, see Notary Bulk Data.

[Print](#)

Notary Search - Detail

Name: MR. ALAN R. EMERMAN
Address: 1812 CLEARVIEW PKWY.
METAIRIE, LA 70001
Phone: (504) 455-1643
Notary ID Number: 36648
Parish: JEFFERSON with STATEWIDE JURISDICTION
Agency: N/A
Notary Type: Attorney
Bar Roll #: 5344
Status: Active
Commission Date: 11/14/1983
Oath Date: 11/10/1983
Surety Expiration Date: Not Required
Annual Report Current: Not Applicable

[Back to Search Results](#)[New Search](#)



CERTIFICATE OF LIABILITY INSURANCE

DATE (MM/DD/YYYY)

7/26/2018

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

IMPORTANT: If the certificate holder is an ADDITIONAL INSURED, the policy(ies) must have ADDITIONAL INSURED provisions or be endorsed. If SUBROGATION IS WAIVED, subject to the terms and conditions of the policy, certain policies may require an endorsement. A statement on this certificate does not confer rights to the certificate holder in lieu of such endorsement(s).

PRODUCER Arthur J. Gallagher Risk Management Services, Inc. 111 Veterans Boulevard, Suite 1130 Metairie LA 70005	CONTACT NAME: Edward J. Murphy PHONE (A/C, No, Ext): 504-888-1100 E-MAIL ADDRESS: Edward_Murphy@ajg.com FAX (A/C, No): 504-888-1299
INSURED Fluid Process & Pumps, LLC 405 Commerce Pt. New Orleans LA 70123	INSURER(S) AFFORDING COVERAGE INSURER A : American Casualty Company of Reading, PA INSURER B : Continental Insurance Company INSURER C : Bridgefield Casualty Insurance Company INSURER D : INSURER E : INSURER F :
FLUIPRO-01	NAIC # 20427 35289 10335

COVERAGES**CERTIFICATE NUMBER:** 992706281**REVISION NUMBER:**

THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.

INSR LTR	TYPE OF INSURANCE	ADDL INSD	SUBR WVD	POLICY NUMBER	POLICY EFF (MM/DD/YYYY)	POLICY EXP (MM/DD/YYYY)	LIMITS
A	<input checked="" type="checkbox"/> COMMERCIAL GENERAL LIABILITY <input type="checkbox"/> CLAIMS-MADE <input checked="" type="checkbox"/> OCCUR GEN'L AGGREGATE LIMIT APPLIES PER: <input type="checkbox"/> POLICY <input type="checkbox"/> PRO-JECT <input checked="" type="checkbox"/> LOC OTHER:			6072074969	6/1/2018	6/1/2019	EACH OCCURRENCE \$ 1,000,000 DAMAGE TO RENTED PREMISES (Ea occurrence) \$ 300,000 MED EXP (Any one person) \$ 15,000 PERSONAL & ADV INJURY \$ 1,000,000 GENERAL AGGREGATE \$ 2,000,000 PRODUCTS - COMP/OP AGG \$ 2,000,000 \$
	AUTOMOBILE LIABILITY <input type="checkbox"/> ANY AUTO <input type="checkbox"/> OWNED AUTOS ONLY <input type="checkbox"/> SCHEDULED AUTOS <input type="checkbox"/> HIRED AUTOS ONLY <input type="checkbox"/> NON-OWNED AUTOS ONLY						COMBINED SINGLE LIMIT (Ea accident) \$ BODILY INJURY (Per person) \$ BODILY INJURY (Per accident) \$ PROPERTY DAMAGE (Per accident) \$ \$
B	<input checked="" type="checkbox"/> UMBRELLA LIAB <input checked="" type="checkbox"/> OCCUR <input type="checkbox"/> EXCESS LIAB <input type="checkbox"/> CLAIMS-MADE <input type="checkbox"/> DED <input checked="" type="checkbox"/> RETENTION \$ 10,000			6072032219	6/1/2018	6/1/2019	EACH OCCURRENCE \$ 4,000,000 AGGREGATE \$ 4,000,000 \$
C	WORKERS COMPENSATION AND EMPLOYERS' LIABILITY ANY PROPRIETOR/PARTNER/EXECUTIVE OFFICER/MEMBER EXCLUDED? (Mandatory in NH) <input type="checkbox"/> Y <input checked="" type="checkbox"/> N If yes, describe under DESCRIPTION OF OPERATIONS below		N/A	19631579	6/1/2018	6/1/2019	<input checked="" type="checkbox"/> PER STATUTE <input type="checkbox"/> OTH-ER E.L. EACH ACCIDENT \$ 1,000,000 E.L. DISEASE - EA EMPLOYEE \$ 1,000,000 E.L. DISEASE - POLICY LIMIT \$ 1,000,000

DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES (ACORD 101, Additional Remarks Schedule, may be attached if more space is required)

General Liability Policy includes the following endorsements, pursuant to and subject to the policy terms, definitions, conditions and exclusions:
Blanket Additional Insured - Owners, Lessees or Contractors - with Products-Completed Operations Coverage-Limited Liability
Endorsement Form # CNA75081XX (1-15)
Blanket Waiver of Subrogation Form # CNA74879XX (1-15)

Worker's Compensation includes Blanket Waiver of Subrogation Form # WC 00 03 13 (4-84)

See Attached...

CERTIFICATE HOLDER**CANCELLATION**

JEFFERSON PARISH PURCHASING DEPT.
200 DERBIGNY ST.
GENERAL GOV'T BLDG, SUITE 4400
BID NO. 50-00123637
GRETN LA 70053

SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS.

AUTHORIZED REPRESENTATIVE

© 1988-2015 ACORD CORPORATION. All rights reserved.

**ADDITIONAL REMARKS SCHEDULE**Page 1 of 1

AGENCY Arthur J. Gallagher Risk Management Services, Inc.		NAMED INSURED Fluid Process & Pumps, LLC 405 Commerce Pt. New Orleans LA 70123
POLICY NUMBER		
CARRIER	NAIC CODE	EFFECTIVE DATE:

ADDITIONAL REMARKS

THIS ADDITIONAL REMARKS FORM IS A SCHEDULE TO ACORD FORM,
FORM NUMBER: 25 FORM TITLE: CERTIFICATE OF LIABILITY INSURANCE

Additional Insured: THE PARISH OF JEFFERSON, IT'S DISTRICTS, DEPARTMENTS & AGENCIES
UNDER THE DIRECTION OF THE PARISH PRESIDENT AND THE PARISH COUNCIL




CERTIFICATE OF LIABILITY INSURANCE

DATE (MM/DD/YYYY)

07/26/2018

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

IMPORTANT: If the certificate holder is an ADDITIONAL INSURED, the policy(ies) must have ADDITIONAL INSURED provisions or be endorsed. If SUBROGATION IS WAIVED, subject to the terms and conditions of the policy, certain policies may require an endorsement. A statement on this certificate does not confer rights to the certificate holder in lieu of such endorsement(s).

PRODUCER  CHUCK MIRAMON 4402 HIGHWAY 22 MANDEVILLE LA 70471		CONTACT NAME: COURTNEY QUALLS PHONE (A/C, No, Ext): 985-626-0200 FAX (A/C, No): 985-626-1003 E-MAIL ADDRESS: COURTNEY.QUALLS.KCD3@STATEFARM.COM	
INSURED FLUID PROCESS & PUMPS LLC PO BOX 10608 NEW ORLEANS LA 70181		INSURER(S) AFFORDING COVERAGE INSURER A: State Farm Mutual Automobile Insurance Company NAIC # 25178 INSURER B: INSURER C: INSURER D: INSURER E: INSURER F:	

COVERAGES**CERTIFICATE NUMBER:****REVISION NUMBER:**

THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.


INSR LTR	TYPE OF INSURANCE	ADDL INSD	SUBR WVD	POLICY NUMBER	POLICY EFF (MM/DD/YYYY)	POLICY EXP (MM/DD/YYYY)	LIMITS
	COMMERCIAL GENERAL LIABILITY <input type="checkbox"/> CLAIMS-MADE <input type="checkbox"/> OCCUR GEN'L AGGREGATE LIMIT APPLIES PER: <input type="checkbox"/> POLICY <input type="checkbox"/> PRO-JECT <input type="checkbox"/> LOC OTHER:						EACH OCCURRENCE \$ DAMAGE TO RENTED PREMISES (Ea occurrence) \$ MED EXP (Any one person) \$ PERSONAL & ADV INJURY \$ GENERAL AGGREGATE \$ PRODUCTS - COM/OP AGG \$ OTHER \$
A	AUTOMOBILE LIABILITY <input checked="" type="checkbox"/> ANY AUTO OWNED AUTOS ONLY <input checked="" type="checkbox"/> SCHEDULED AUTOS NON-OWNED AUTOS ONLY <input type="checkbox"/> HIRED AUTOS ONLY	Y	Y	031-4652,031-4654,031-4655 031-4659,031-4664,068-3193, 076-5600,102-4519,129-2175 145-6073,165-3271,315-5292	09/19/2017 09/19/2017 09/19/2017 09/19/2017	03/19/2018 03/19/2018 03/19/2018 03/19/2018	COMBINED SINGLE LIMIT (Ea accident) \$ 2,000,000 BODILY INJURY (Per person) \$ BODILY INJURY (Per accident) \$ PROPERTY DAMAGE (Per accident) \$ OTHER \$
	UMBRELLA LIAB <input type="checkbox"/> OCCUR EXCESS LIAB <input type="checkbox"/> CLAIMS-MADE DED <input type="checkbox"/> RETENTION \$						EACH OCCURRENCE \$ AGGREGATE \$ OTHER \$
	WORKERS COMPENSATION AND EMPLOYERS' LIABILITY ANY PROPRIETOR/PARTNER/EXECUTIVE OFFICER/MEMBER EXCLUDED? (Mandatory in NH) If yes, describe under DESCRIPTION OF OPERATIONS below	Y/N	N/A				PER STATUTE <input type="checkbox"/> OTH-ER <input type="checkbox"/> E.L. EACH ACCIDENT \$ E.L. DISEASE - EA EMPLOYEE \$ E.L. DISEASE - POLICY LIMIT \$

DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES (ACORD 101, Additional Remarks Schedule, may be attached if more space is required)

Please add certificate holder as an additional insured as indicated:

THE PARISH OF JEFFERSON, IT'S DISTRICTS, DEPARTMENTS & AGENCIES
UNDER THE DIRECTION OF THE PARISH PRESIDENT AND THE PARISH COUNCIL

CERTIFICATE HOLDER**CANCELLATION**

Jefferson Parish Purchasing Dept. 200 Debigny St. General Gov't Bldg, Suite 4400 Bid No. 50-00123637 Gretna LA 70053	SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS. AUTHORIZED REPRESENTATIVE 
---	---

© 1988-2015 ACORD CORPORATION. All rights reserved.

Request for Taxpayer Identification Number and Certification

► Go to www.irs.gov/FormW9 for instructions and the latest information.

Give Form to the
requester. Do not
send to the IRS.

Print or type. See Specific Instructions on page 3.	1 Name (as shown on your income tax return). Name is required on this line; do not leave this line blank. FLUID PROCESS & PUMPS, LLC	
	2 Business name/disregarded entity name, if different from above	
	3 Check appropriate box for federal tax classification of the person whose name is entered on line 1. Check only one of the following seven boxes. <input type="checkbox"/> Individual/sole proprietor or single-member LLC <input type="checkbox"/> C Corporation <input type="checkbox"/> S Corporation <input type="checkbox"/> Partnership <input type="checkbox"/> Trust/estate <input checked="" type="checkbox"/> Limited liability company. Enter the tax classification (C=C corporation, S=S corporation, P=Partnership) ► <u>S</u> Note: Check the appropriate box in the line above for the tax classification of the single-member owner. Do not check LLC if the LLC is classified as a single-member LLC that is disregarded from the owner unless the owner of the LLC is another LLC that is not disregarded from the owner for U.S. federal tax purposes. Otherwise, a single-member LLC that is disregarded from the owner should check the appropriate box for the tax classification of its owner. <input type="checkbox"/> Other (see instructions) ►	
	4 Exemptions (codes apply only to certain entities, not individuals; see instructions on page 3): Exempt payee code (if any) _____ Exemption from FATCA reporting code (if any) _____ (Applies to accounts maintained outside the U.S.)	
	5 Address (number, street, and apt. or suite no.) See instructions. P. O. BOX 10608	Requester's name and address (optional) Jefferson Parish
	6 City, state, and ZIP code NEW ORLEANS, LA 70181	
	7 List account number(s) here (optional)	

Part I Taxpayer Identification Number (TIN)

Enter your TIN in the appropriate box. The TIN provided must match the name given on line 1 to avoid backup withholding. For individuals, this is generally your social security number (SSN). However, for a resident alien, sole proprietor, or disregarded entity, see the instructions for Part I, later. For other entities, it is your employer identification number (EIN). If you do not have a number, see *How to get a TIN*, later.

Note: If the account is in more than one name, see the instructions for line 1. Also see *What Name and Number To Give the Requester* for guidelines on whose number to enter.

Social security number									
				-					
OR									
Employer identification number									
2	7		-	2	3	1	2	5	6 1

Part II Certification

Under penalties of perjury, I certify that:

1. The number shown on this form is my correct taxpayer identification number (or I am waiting for a number to be issued to me); and
2. I am not subject to backup withholding because: (a) I am exempt from backup withholding, or (b) I have not been notified by the Internal Revenue Service (IRS) that I am subject to backup withholding as a result of a failure to report all interest or dividends, or (c) the IRS has notified me that I am no longer subject to backup withholding; and
3. I am a U.S. citizen or other U.S. person (defined below); and
4. The FATCA code(s) entered on this form (if any) indicating that I am exempt from FATCA reporting is correct.

Certification instructions. You must cross out item 2 above if you have been notified by the IRS that you are currently subject to backup withholding because you have failed to report all interest and dividends on your tax return. For real estate transactions, item 2 does not apply. For mortgage interest paid, acquisition or abandonment of secured property, cancellation of debt, contributions to an individual retirement arrangement (IRA), and generally, payments other than interest and dividends, you are not required to sign the certification, but you must provide your correct TIN. See the instructions for Part II, later.

Sign
Here

Signature of
U.S. person ►

Date ► 07/27/18

General Instructions

Section references are to the Internal Revenue Code unless otherwise noted.

Future developments. For the latest information about developments related to Form W-9 and its instructions, such as legislation enacted after they were published, go to www.irs.gov/FormW9.

Purpose of Form

An individual or entity (Form W-9 requester) who is required to file an information return with the IRS must obtain your correct taxpayer identification number (TIN) which may be your social security number (SSN), individual taxpayer identification number (ITIN), adoption taxpayer identification number (ATIN), or employer identification number (EIN), to report on an information return the amount paid to you, or other amount reportable on an information return. Examples of information returns include, but are not limited to, the following.

- Form 1099-INT (interest earned or paid)

- Form 1099-DIV (dividends, including those from stocks or mutual funds)
- Form 1099-MISC (various types of income, prizes, awards, or gross proceeds)
- Form 1099-B (stock or mutual fund sales and certain other transactions by brokers)
- Form 1099-S (proceeds from real estate transactions)
- Form 1099-K (merchant card and third party network transactions)
- Form 1098 (home mortgage interest), 1098-E (student loan interest), 1098-T (tuition)
- Form 1099-C (canceled debt)
- Form 1099-A (acquisition or abandonment of secured property)

Use Form W-9 only if you are a U.S. person (including a resident alien), to provide your correct TIN.

If you do not return Form W-9 to the requester with a TIN, you might be subject to backup withholding. See What is backup withholding, later.



JEFFERSON PARISH

Department of Purchasing

Michael S. Yenni
Parish President

Renny Simno
Director

July 23, 2018

ADDENDUM # 1

Bid No.: 50-00123637

Bid Opening Date: 08/2/2018

**For: One time purchase of 8 inch submersible non-clog sewer pumps for Jefferson Parish
Department of Drainage.**

REPLACE ALL THE SPECIFICATION SHEETS WITH ATTACHED REVISED SHEETS.

Some of the important information was inadvertently left out.

Sincerely,

Donna Reamey

Donna Reamey, Buyer II
Jefferson Parish Purchasing Department

**Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of
this addendum on the bid form as indicated. Failure to do so will result in bid rejection.**

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.

REVISED SPECIFICATION FOR BID # 50-123637

SPECIFICATIONS 8 INCH SUBMERSIBLE NON-CLOG SEWER PUMP JEFFERSON PARISH DEPT. OF SEWERAGE PAGE & LONGFELLOW SEWER LIFT STATION

1.01 GENERAL

- A. The bidder shall supply three (3) submersible explosion-proof, premium efficiency, solids handling pumps for the Page & Longfellow Sewer Lift Station. Said pumps must be able to fit the existing rail system, utilize the existing sealing flange, and fit into the aluminum hatches at the Page & Longfellow Sewer Lift Station. The pumps shall be able to match the hydraulic performance limits listed in these specifications. The pump motors shall bear a stainless steel nametag showing FM approval for Class I Division I explosion proof environments. The pumps shall be supplied by a factory authorized agent for Jefferson Parish, and shall match up to and utilize the existing rail system and hatch doors with no modifications to the existing pump station or rail system. The pumps on this bid shall, at the owner's option, have a complete certified Hydraulic Institute pump test performed in the same facility that it was manufactured in. This hydraulic test shall certify at least seven (7) separate operating points along its operating curve, including the duty point and shut-off, and show GPM, TDH, efficiency, and BHP at each tested point. These certified curves shall be approved by the owner or the owner's appointed agent before the pump can be released for shipment. The owner reserves the right to cancel any bids that are incomplete, or do not demonstrate that they are equal to the requirements of these specifications.

2.01 OPERATING CONDITIONS

- A. Each pump shall be rated 40 H.P., 460 volts, 3 phase, 60 hertz, maximum 1150 R.P.M. The unit shall produce 1500 GPM at 67 feet TDH, with a minimum pump efficiency of 75 percent and maximum input KW of 36.5. Each pump shall be capable of handling a minimum 4 inch spherical solid. Each pump shall be non-overloading throughout the entire range of operation without employing service factor. Each pump shall have an auxiliary duty point of 3100 GPM @ 39 feet TDH, with a minimum 74 percent pump efficiency. Each pump shall have a minimum shut off head of 108 feet. Each pump motor shall reserve a minimum service factor of 1.3. The performance curve shall state, in addition to head and capacity performance, the pump efficiency, solids handling capacity, and reflect motor service factor.

3.01 CONSTRUCTION

- A. Each pump shall be centrifugal, non-clog, solids handling, submersible, wastewater type; model S8LXP as manufactured by Hydromatic Pumps, or approved equal. Each pump must bear a stainless steel manufacturer's nameplate stating Made in the U.S.A., or Assembled in the U.S.A. Each pump volute, motor, and seal housing shall be high quality gray cast iron, ASTM A-48, Class 30. Each pump discharge shall be fitted with an 8 inch standard ASA 125-lb. flange, faced and drilled. Slotted flange bolt holes will not be accepted. All external mating parts shall be machined and Buna N Rubber O-ring sealed on a beveled edge. Gaskets will not be accepted. All fasteners exposed to the pumped liquids shall be 300 series stainless steel.
- B. All equipment shall be new and furnished as required for an installation incorporating the highest standards for this type of service. The successful bidder shall also supply, as minimum, one (1) full day of supervisory services during installation and field testing of each unit, and instruct all operating personnel in the proper care, operation, and maintenance of the equipment. Field testing results shall be furnished to the owner in writing, and shall include all pertinent data recorded such as voltage, amperage, and insulation resistance values, along with the factory certified technicians name, date, and signature.

REVISED SPECIFICATION FOR BID # 50-123637

3.02 ELECTRICAL POWER CORD

- A. Each electrical power cord shall be 50 feet long and made of STW-A, water resistant 600 V, 60° Celsius, UL and CSA listed, and applied dependent on amp draw for size. Each pump shall have an independent sensor cord containing motor overtemp and moisture sensor wires.
- B. Each pump shall be double protected with a compression fitting and epoxy potted area at the power cord entry to the pump. A separation between the junction box area of the pump and the motor by a stator lead sealing gland or terminal board will not be accepted.
- C. The power cable entry into the cord cap assembly shall first be made with a compression fitting. Each individual lead shall be stripped down to bare wire at staggered intervals, and each strand shall be individually separated. This area of the cord cap shall then be filled with an epoxy compound potting, which will prevent water contamination to gain entry, even in the event of wicking or capillary attraction.
- D. The power cord leads shall then be connected to the motor leads with extra heavy connectors having brass inserts with a screwed wire to wire connection, rather than a terminal board that allows for possible leaks.
- E. The cord cap assembly where bolted to the connection box assembly and the connection box assembly where bolted to the motor housing shall each be sealed with a Buna N Rubber O-ring on a beveled edge to assure proper sealing.

3.03 MOTOR

- A. The stator, rotor, and bearings shall be mounted in a sealed and oil filled submersible type housing. The stator windings shall have a minimum Class H insulation (180°C or 356°F), NEMA B design (3-phase). Air filled designs will not be accepted. Further protection shall be provided by "on winding" thermal sensors.
- B. Each pump and motor shall be specifically designed so that they may be operated partially or completely submerged in the liquid being pumped.
- C. Each motor stator shall be slip fit mounted into the watertight casing. Stators must be capable of being repaired or rewound by local motor service facilities. Heat shrink motor fits, will not be accepted. No special tools shall be required for pump and motor disassembly.
- D. Each motor shall be equipped with integral heat sensors, one for each phase (three phase motor). The heat sensor(s) shall be a low resistance; bi-metal disc that is temperature sensitive. They shall be mounted directly on the stator windings. The sensors shall be connected in series with motor starter coil so that the pump ceases operation when an over-temperature condition is sensed. These sensors shall be used in conjunction with and supplemented by external motor over-current protection located at the control panel. The pump shall cease operation when the overload is tripped. The overload shall be manually reset.
- E. Motors shall have a service factor of 1.3 or greater.
- F. Cable Entry: The cable entry water seal design shall be such that it precludes specific torque requirements to ensure a watertight and submersible seal. It shall permit no entry of water into any high voltage area, even if the cable is severed below the water level.
- G. Cooling System: Each pump shall be provided with an adequately designed cooling system. Water jackets or closed loop cooling systems will not be accepted.
- H. Motors shall conform to the NEMA Premium Efficiency Electric Motor Program.

REVISED SPECIFICATION FOR BID # 50-123637

Motors must meet or exceed the nominal energy efficiency levels listed in NEMA standards publication MG 1-2006, tables 12-12 and 12-13.

3.04 BEARINGS AND SHAFT

- A. An upper radial bearing and a lower thrust bearing are required. These shall be heavy-duty single row ball bearings, which are permanently lubricated by the dielectric oil which fills the motor housing. Sealed grease packed bearings will not be accepted. Bearings that require lubrication according to a prescribed schedule will not be accepted. The upper radial bearing shall have a minimum B-10 life at the specified condition of 50,000 hours and the lower double row thrust bearing shall have a minimum B-10 life at the specified condition of 50,000 hours. Bearings must be locally available.
- B. The shaft shall be machined from a solid 416 series stainless steel forging, and of a design that is large diameter with minimum overhang, to reduce shaft deflection and prolong bearing life.

3.05 SEALS

- A. Each pump shall have two mechanical seals, mounted in tandem, with an oil chamber between the seals. Seals shall be used with the rotating seal faces being carbon and the stationary seal faces to be silicone carbide. The lower seal shall be replaceable without disassembly of the seal chamber and without the use of special tools. Pump-out vanes shall be present on the backside of the impeller to keep contaminants out of the seal area. Units that require the use of foreign manufactured seals will not be accepted. Seals must be locally available.
- B. Each pump shall be equipped with a seal leak detection probe and warning system. This shall be designed to alert maintenance personnel of lower seal failure without having to take the unit out of service for inspection, or requiring access for checking seal chamber oil level and consistency.
- C. There shall be an electric probe or seal failure sensor installed in the seal chamber between the two tandem mechanical seals. The seal fail circuit shall use a probe that has no moving parts. If the lower seal fails, contaminants which enter the seal chamber shall be detected by the sensor and send a signal to operate the specified warning device.
- D. Units equipped with opposed mechanical seals will not be accepted.

3.06 IMPELLER

- A. Impellers shall be of the two-vane, enclosed non-clogging design and have pump-out vanes on the front and backside of the impeller to prevent grit and other materials from collecting in the seal area. Single vane design impellers which cannot be easily trimmed, and which do not maintain balance with wear, causing shaft deflections and reducing seal and bearing life will not be accepted. Impeller shall not require coating. Because most impeller coatings do not remain beyond the very early life of the impeller, efficiency and other performance data submitted shall be based on performance with an uncoated impeller. Attempts to improve efficiency by coating impellers will not be acceptable. The impeller shall be manufactured from ductile iron ASTM A-536 material.
- B. Impellers shall be dynamically balanced. The tolerance values shall be as listed below, according to the International Standard Organization grade 6.3 for rotors in rigid frames. The tolerance is to be split equally between the two balance planes, which are the two impeller shrouds.

RPM	Tolerance
1150	.026 in. - oz./lb. of impeller weight
- C. The impeller shall be slip fit to a tapered shaft and key driven. A 300 series stainless steel washer and impeller bolt shall be used to fasten the impeller to the shaft. Straight end or threaded shafts for attachment of the impeller will not be accepted.

REVISED SPECIFICATION FOR BID # 50-123637

3.07 CASING

- A. The casing shall be of the end suction volute type, having sufficient strength and thickness to withstand all stress and strain from service at full operating pressure and load. The casing shall be of the centerline horizontal discharge type. The design shall be such that the pumps will be automatically connected to the discharge piping when lowered into position with the guide rails. The casing shall be accurately machined and bored for register fits with the suction and casing covers.
- B. A volute case wearing ring shall be provided to minimize impeller wear. The wear ring shall be 300 series stainless steel or bronze ASTM # B584-932, and held by 300 series stainless steel fasteners. The wear ring shall be easily replaceable in the field. Wear rings of any other material will not be accepted.

3.08 PAINTING

- A. Each pump shall be painted after assembly and testing, with a dark green water reducible air dry enamel. The paint shall be applied in one coat, covering all exterior surfaces. The pump shall be air dried after testing and before painting.

3.09 SERVICEABILITY

- A. The complete rotating assembly shall be capable of being removed from the volute without disturbing discharge piping or volute. The motor housing, seal housing with seal plate, and impeller still attached to the shaft shall be capable of being lifted out of the volute case from the top as one assembly.

3.10 SUPPORT

- A. Though the pumps may not require feet to support the units while installed, the pump volutes must have feet to support the units when removed for service. Units which do not have feet upon which the unit can be supported when removed for service will not be accepted.

4.01 TESTING

- A. Commercial testing shall be required, and include the following:
 - 1. Each pump shall be visually inspected to confirm that it is built in accordance with the specification as to HP, voltage, phase, and hertz.
 - 2. The stator motor leads shall be tested for integrity using a meg-ohm meter at the highest setting.
 - 3. Each pump shall be allowed to run dry to check for proper rotation.
 - 4. Discharge piping shall be attached; each pump shall be submerged in water and amp readings shall be taken in each leg to check for an imbalanced stator winding. If there is a significant difference in readings, the stator windings shall be checked with a bridge to determine if an unbalanced resistance exists. If so, the stator shall be replaced.
 - 5. Each pump shall be removed from the water, meg-ohm meter tested again, dried, and the motor housings shall be filled with dielectric oil.

5.01 SERVICE AND WARRANTY

- A. The pump manufacturer shall have an authorized factory service center, capable of completely servicing the proposed pumps within one (1) hour of the project site. The pump manufacturer shall have a direct factory service center/stocking facility capable of completely servicing and providing spare parts for the proposed pumps within one (1) hour of the project site.

REVISED SPECIFICATION FOR BID # 50-123637

- B. Each pump unit or any part thereof shall be warranted against defects in material or workmanship within one year from date of installation, or 18 months from date of manufacture, whichever comes first, and shall be replaced at no charge with a new or manufactured part, F.O.B. factory or authorized warranty service station. The warranty shall not assume responsibility for removal, reinstallation or freight, nor shall it assume responsibility of incidental damages resulting from the failure of the pump to perform. The warranty shall not apply to damage resulting from accident, alteration, design, misuse, or abuse.

SPECIFICATIONS FOR BID # 50-00123637

SPECIFICATIONS 8 INCH SUBMERSIBLE NON-CLOG SEWER PUMP JEFFERSON PARISH DEPT. OF SEWERAGE PAGE & LONGFELLOW SEWER LIFT STATION

1.01 GENERAL

- A. The bidder shall supply three (3) submersible explosion-proof, premium efficiency, solids handling pumps for the Page & Longfellow Sewer Lift Station. Said pumps must be able to fit the existing rail system, utilize the existing sealing flange, and fit into the aluminum hatches at the Page & Longfellow Sewer Lift Station. The pumps shall be able to match the hydraulic performance limits listed in these specifications. The pump motors shall bear a stainless steel nametag showing FM approval for Class I Division I explosion proof environments. The pumps shall be supplied by a factory authorized agent for Jefferson Parish, and shall match up to and utilize the existing rail system and hatch doors with no modifications to the existing pump station or rail system. The Owner reserves the right to cancel any and all bids or bids that are incomplete or do not demonstrate that they are equal to the requirements of these specifications.

2.01 OPERATING CONDITIONS

- A. Each pump shall be rated 40 H.P., 460 volts, 3 phase, 60 hertz, maximum 1150 R.P.M. The unit shall produce 1500 GPM at 67 ft TDH, with a minimum pump efficiency of 75% and maximum input KW of 36.5. Each pump shall be capable of handling a minimum 4 inch spherical solid. Each pump shall be non-overloading throughout the entire range of operation without employing service factor. Each pump shall have an auxiliary duty point of 3100 GPM @ 39 ft TDH, with a minimum 74% pump efficiency. Each pump shall have a minimum shut off head of 108 feet. Each pump motor shall reserve a minimum service factor of 1.3. The performance curve shall state, in addition to head and capacity performance, the pump efficiency, solids handling capacity, and reflect motor service factor.

3.01 CONSTRUCTION

- A. Each pump shall be centrifugal, non-clog, solids handling, submersible, wastewater type; model S8LXP as manufactured by Hydromatic Pumps, or approved equal. Each pump volute, motor, and seal housing shall be high quality gray cast iron, ASTM A-48, Class 30. Each pump discharge shall be fitted with an 8 inch standard ASA 125-lb. flange, faced

SPECIFICATIONS FOR BID # 50-00123637

and drilled. Slotted flange bolt holes will not be accepted. All external mating parts shall be machined and Buna N Rubber O-ring sealed on a beveled edge. Gaskets will not be accepted. All fasteners exposed to the pumped liquids shall be 300 series stainless steel.

3.02 ELECTRICAL POWER CORD

- A. Each electrical power cord shall be 50 feet long and made of STW-A, water resistant 600 V, 60°C., UL and CSA listed, and applied dependent on amp draw for size. Each pump shall have an independent sensor cord containing motor overtemp and moisture sensor wires.
- B. Each pump shall be double protected with a compression fitting and epoxy potted area at the power cord entry to the pump. A separation between the junction box area of the pump and the motor by a stator lead sealing gland or terminal board will not be accepted.
- C. The power cable entry into the cord cap assembly shall first be made with a compression fitting. Each individual lead shall be stripped down to bare wire at staggered intervals, and each strand shall be individually separated. This area of the cord cap shall then be filled with an epoxy compound potting, which will prevent water contamination to gain entry, even in the event of wicking or capillary attraction.
- D. The power cord leads shall then be connected to the motor leads with extra heavy connectors having brass inserts with a screwed wire to wire connection, rather than a terminal board that allows for possible leaks.
- E. The cord cap assembly where bolted to the connection box assembly and the connection box assembly where bolted to the motor housing shall each be sealed with a Buna N Rubber O-ring on a beveled edge to assure proper sealing.

3.03 MOTOR

- A. The stator, rotor, and bearings shall be mounted in a sealed and oil filled submersible type housing. The stator windings shall have a minimum Class H insulation (180°C or 356°F), NEMA B design (3-phase). Air filled designs will

SPECIFICATIONS FOR BID # 50-00123637

not be accepted. Further protection shall be provided by "on winding" thermal sensors.

- B. Each pump and motor shall be specifically designed so that they may be operated partially or completely submerged in the liquid being pumped.
- C. Each motor stator shall be slip fit mounted into the watertight casing. Stators must be capable of being repaired or rewound by local motor service facilities. Heat shrink motor fits, will not be accepted. No special tools shall be required for pump and motor disassembly.
- D. Each motor shall be equipped with integral heat sensors, one for each phase (three phase motor). The heat sensor(s) shall be a low resistance; bi-metal disc that is temperature sensitive. They shall be mounted directly on the stator windings. The sensors shall be connected in series with motor starter coil so that the pump ceases operation when an over-temperature condition is sensed. These sensors shall be used in conjunction with and supplemented by external motor over-current protection located at the control panel. The pump shall cease operation when the overload is tripped. The overload shall be manually reset.
- E. Motors shall have a service factor of 1.3 or greater.
- F. Cable Entry: The cable entry water seal design shall be such that it precludes specific torque requirements to ensure a watertight and submersible seal. It shall permit no entry of water into any high voltage area, even if the cable is severed below the water level.
- G. Cooling System: Each pump shall be provided with an adequately designed cooling system. Water jackets or closed loop cooling systems will not be accepted.
- H. Motors shall conform to the NEMA Premium Efficiency Electric Motor Program.

Motors must meet or exceed the nominal energy efficiency levels listed in NEMA

SPECIFICATIONS FOR BID # 50-00123637

standards publication MG 1-2006, tables 12-12 and 12-13.

3.04 BEARINGS AND SHAFT

- A. An upper radial bearing and a lower thrust bearing are required. These shall be heavy-duty single row ball bearings, which are permanently lubricated by the dielectric oil which fills the motor housing. Sealed grease packed bearings will not be accepted. Bearings that require lubrication according to a prescribed schedule will not be accepted. The upper radial bearing shall have a minimum B-10 life at the specified condition of 50,000 hours and the lower double row thrust bearing shall have a minimum B-10 life at the specified condition of 50,000 hours. Bearings must be locally available.
- B. The shaft shall be machined from a solid 416 series stainless steel forging, and of a design that is large diameter with minimum overhang, to reduce shaft deflection and prolong bearing life.

3.05 SEALS

- A. Each pump shall have two mechanical seals, mounted in tandem, with an oil chamber between the seals. Seals shall be used with the rotating seal faces being carbon and the stationary seal faces to be silicone carbide. The lower seal shall be replaceable without disassembly of the seal chamber and without the use of special tools. Pump-out vanes shall be present on the backside of the impeller to keep contaminants out of the seal area. Units that require the use of foreign manufactured seals will not be accepted. Seals must be locally available.
- B. Each pump shall be equipped with a seal leak detection probe and warning system. This shall be designed to alert maintenance personnel of lower seal failure without having to take the unit out of service for inspection, or requiring access for checking seal chamber oil level and consistency.
- C. There shall be an electric probe or seal failure sensor installed in the seal chamber between the two tandem mechanical seals. The seal fail circuit shall use a probe that has no moving parts. If the lower seal fails, contaminants which enter the seal chamber shall be detected by the sensor and send a signal to operate the specified warning device.

SPECIFICATIONS FOR BID # 50-00123637

- D. Units equipped with opposed mechanical seals will not be accepted.

3.06 IMPELLER

- A. Impellers shall be of the two-vane, enclosed non-clogging design and have pump-out vanes on the front and backside of the impeller to prevent grit and other materials from collecting in the seal area. Single vane design impellers which cannot be easily trimmed, and which do not maintain balance with wear, causing shaft deflections and reducing seal and bearing life will not be accepted. Impeller shall not require coating. Because most impeller coatings do not remain beyond the very early life of the impeller, efficiency and other performance data submitted shall be based on performance with an uncoated impeller. Attempts to improve efficiency by coating impellers will not be acceptable. The impeller shall be manufactured from ductile iron ASTM A-536 material.
- B. Impellers shall be dynamically balanced. The tolerance values shall be as listed below, according to the International Standard Organization grade 6.3 for rotors in rigid frames. The tolerance is to be split equally between the two balance planes, which are the two impeller shrouds.

RPM Tolerance

1150 .026 in. - oz./lb. of impeller weight

- C. The impeller shall be slip fit to a tapered shaft and key driven. A 300 series stainless steel washer and impeller bolt shall be used to fasten the impeller to the shaft. Straight end or threaded shafts for attachment of the impeller will not be accepted.

3.07 CASING

- A. The casing shall be of the end suction volute type, having sufficient strength and thickness to withstand all stress and strain from service at full operating pressure and load. The casing shall be of the centerline horizontal discharge type. The design shall be such that the pumps will be automatically connected to the discharge piping when lowered into position with the guide rails. The casing shall be accurately machined and bored for register fits with the suction and casing covers.
- B. A volute case wearing ring shall be provided to minimize impeller wear. The wear ring shall be 300 series stainless steel or bronze ASTM # B584-932, and held by 300 series stainless steel fasteners. The wear ring shall be easily replaceable in the field. Wear rings of any other material will not be accepted.

SPECIFICATIONS FOR BID # 50-00123637

3.08 PAINTING

- A. Each pump shall be painted after assembly and testing, with a dark green water reducible air dry enamel. The paint shall be applied in one coat, covering all exterior surfaces. The pump shall be air dried after testing and before painting.

3.09 SERVICEABILITY

- A. The complete rotating assembly shall be capable of being removed from the volute without disturbing discharge piping or volute. The motor housing, seal housing with seal plate, and impeller still attached to the shaft shall be capable of being lifted out of the volute case from the top as one assembly.

3.10 SUPPORT

- A. Though the pumps may not require feet to support the units while installed, the pump volutes must have feet to support the units when removed for service. Units which do not have feet upon which the unit can be supported when removed for service will not be accepted.

4.01 TESTING

- A. Commercial testing shall be required, and include the following:
 - 1. Each pump shall be visually inspected to confirm that it is built in accordance with the specification as to HP, voltage, phase, and hertz.
 - 2. The stator motor leads shall be tested for integrity using a meg-ohm meter at the highest setting.
 - 3. Each pump shall be allowed to run dry to check for proper rotation.

SPECIFICATIONS FOR BID # 50-00123637

4. Discharge piping shall be attached; each pump shall be submerged in water and amp readings shall be taken in each leg to check for an imbalanced stator winding. If there is a significant difference in readings, the stator windings shall be checked with a bridge to determine if an unbalanced resistance exists. If so, the stator shall be replaced.
5. Each pump shall be removed from the water, meg-ohm meter tested again, dried, and the motor housings shall be filled with dielectric oil.

5.01 SERVICE AND WARRANTY

- A. The pump manufacturer shall have an authorized factory service center, capable of completely servicing the proposed pumps. The pump manufacturer shall have a direct factory service center/stocking facility capable of completely servicing and providing spare parts for the proposed pumps.
- B. Each pump unit or any part thereof shall be warranted against defects in material or workmanship within one year from date of installation, or 18 months from date of manufacture, whichever comes first, and shall be replaced at no charge with a new or manufactured part, F.O.B. factory or authorized warranty service station. The warranty shall not assume responsibility for removal, reinstallation or freight, nor shall it assume responsibility of incidental damages resulting from the failure of the pump to perform. The warranty shall not apply to damage resulting from accident, alteration, design, misuse, or abuse.