

DATE: 3/12/2018

INVITATION TO BID
THIS IS NOT AN ORDER

Page: 4

BID NO.: 50-00122516

JEFFERSON PARISH

PURCHASING DEPARTMENT
P.O. BOX 9
GRETNA, LA. 70054-0009
504-364-2678

PEMBA Inc.

VENDOR: 27118 BLANK BID COPY VENDOR

BUYER: DMEVANS

As per LSA-RS 47:301 et seq., all governmental bodies are excluded from payment of sales taxes to any Louisiana taxing body. Quotations shall be based on F.O.B. Agency warehouse or jobsite, anywhere within the Parish as designated by the Purchasing Department.

JEFFERSON PARISH reserves the right to cancel all or any part of an order if not shipped promptly. No charges will be allowed for parking or cartage unless specified in quotation. The order must not be filled at a higher price than quoted. JEFFERSON PARISH reserves the right to cancel at any time and for any reason by issuing a THIRTY (30) day written notice to the contractor.

JEFFERSON PARISH is expecting all products to be new and all work to be done in workman-like manner, according to standard practices. Any deviations or alteration from the specifications must be indicated on the bid form for each item and upon request, product data for same must be submitted by the time specified by the Purchasing Department.

DELIVERY: FOB JEFFERSON PARISH	
INDICATE DELIVERY DATE ON EQUIPMENT AND SUPPLIES	<u>3-4 weeks</u>
INDICATE STARTING TIME (IN DAYS) FOR CONSTRUCTION WORK	<u>N/A</u>
INDICATE COMPLETION TIME (IN DAYS) FOR CONSTRUCTION WORK	<u>N/A</u>

In the event that addenda are issued with this bid, bidders MUST acknowledge all addenda on the bid form. Bidder must acknowledge receipt of an addendum on the bid form as indicated. Failure to acknowledge any addendum on the bid form will result in bid rejection.

Acknowledge Receipt of Addenda: NUMBER: Addendum #1
NUMBER: _____
NUMBER: _____
NUMBER: _____

LOUISIANA CONTRACTOR'S LICENSE NO.: (if applicable) _____

*** ALL BIDDERS MUST COMPLETE SECTION BELOW ***	
FIRM NAME: PEMBA Inc.	
SIGNATURE: (Must be signed here) <i>Patricia Smith</i>	TITLE: Owner
PRINT OR TYPE NAME: Patricia Smith	
ADDRESS: 104 P. Street	
CITY, STATE: Belle Chasse, LA	ZIP: 70037
TELEPHONE: (504) 394-4132	FAX: (504) 303-4394
EMAIL ADDRESS: patricias@pemba.biz	

TOTAL PRICE OF ALL BID ITEMS: \$ \$11,576.10

INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00122516

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
1	12.00	EA	ONE TIME PURCHASE OF LIGHT FIXTURES 0010 LTH TSP 1000M GP24M 480 SCWA LPI OEM	\$479.54	\$5,754.45
2	12.00	EA	0020 LTH TSP 1000M GP24M TB SCWA WITH LAMP OEM To be used for electrical division Lithonia Quoted Freight Included	\$485.14	\$5,821.65

FEATURES & SPECIFICATIONS

INTENDED USE — Use for stadiums, fields, arenas, tracks or courts.

CONSTRUCTION — Two-piece die-cast aluminum ballast housing mounted to galvanized steel trunnion. Ballast is removable and hinged with captive fastener. Steel trunnion features vertical and horizontal aiming scale with vertical repositioning stop. All external hardware is stainless steel.

Finish: White corrosion resistant polyester powder finish standard (DWH); other architectural colors available.

OPTICS — Heavy-gauge anodized reflector with five distributions available. "Flux manager" available for optimal glare and spill light control. Transverse mounting of lamp. Lamp support included. Optical chamber sealed to inhibit entrance of contaminants. Hinged lens is thermal-, shock- and impact-resistant tempered glass. Lens frame is galvanized and secured by stainless steel spring clips for servicing of lamp. Aiming device included to assist in positioning luminaire. **US. Patent no. 6,190,023. Canada Patent no. 2,212,014.**

ELECTRICAL — All electrical components are thermally isolated from the optical assembly, promoting longer life. Ballast is high power factor, constant-wattage autotransformer and 100% factory tested. Super CWA Pulse Start ballasts, DOE2017 compliant, are required for 400W (must order SCWA option) for US shipments only. CSA, NOM or INTL required for probe start shipments outside of the U.S.

Die-cast socket housing. Mogul-base porcelain socket with copper alloy, nickel-plated screw shell and spring-loaded center contact. U.L. listed 1500W - 600V.

INSTALLATION — Fixture mounted by securing trunnion directly to cross arm. No additional adaptors required. Mounting hardware provided.

LISTINGS — UL listed, suitable for wet locations. Below horizontal aiming orientation only. Listed and labeled to comply with Canadian Standards (see Options).

WARRANTY — 1-year limited warranty. Complete warranty terms located at: www.acuitybrands.com/CustomerResources/Terms_and_conditions.aspx

Note: Actual performance may differ as a result of end-user environment and application. Specifications subject to change without notice.


Catalog Number
Notes
Type



Sportlighting

TSP

METAL HALIDE: 400W, 1000W, 1500W
Below Horizontal Aiming Orientation Only



EPA: 3.3 ft² (0.31m²)
Diameter: 24-1/2 (62.2)
Length: 20 (50.8)
*Max. Weight: 55 lbs. (24.9 kg)

All dimensions are inches (centimeters) unless otherwise indicated.
*Weight as configured in example below.

ORDERING INFORMATION

For shortest lead times, configure product using **standard options (shown in bold)**.

Example: TSP 1500M GP24N TB

Series	Wattage	Distribution	Voltage	Ballast	Mounting	
TSP	400M ¹ 1000M² 1500M	General purpose GP24N GP24NFX GP24M GP24MFX GP24W GP24WFX	Heavy duty ³ HD24N HD24NFX HD24M HD24MFX HD24W HD24WFX	120 208 ⁴ 240 ⁴ 277 347 480⁴ TB⁵ 23050HZ ⁶	(blank) Magnetic ballast CWI Constant wattage isolated ⁶ Pulse Start SCWA Super constant wattage autotransformer⁷ Note: For shipments to U.S. territories, SCWA must be specified to comply with EISA.	Shipped installed (blank) Yoke Shipped separately ⁸ FPMB Pipe mounting bracket FSAB Steel angle bracket for FTS FRWB Radius wall bracket for FTS FCRA Cross arm adapter FCRA45 Cross arm adapter (45° mount) ⁹ FTS Tenon slipfitter
Options					Finish ¹³	
Shipped installed in fixture					(blank) White	
SF	Single fuse (120, 277, 347V) N/A TB	CF	Charcoal filter (heavy duty only) ¹²	DDB	Dark bronze	
DF	Double fuse (208, 240, 480V) N/A TB	SLR	Stainless steel lens ring	DBL	Black	
QRS	Quartz restrrike system ¹⁰	WC	Wood cross arm mounting bolt (5/8" - 11 UNC x 7")	DMB	Medium bronze	
C62	2 ft. of 16/3 SEO cable pre-wired	CSA	Listed and labeled to comply with Canadian Standards (120, 277, 347V only)	DNA	Natural aluminum	
C42	2 ft. of 14/3 SEO cable pre-wired	INTL	Available for MH probe start shipping outside the U.S.	CR	Enhanced corrosion-resistance	
C22	2 ft. of 12/3 SEO cable pre-wired	REGC1	California Title 20 effective 1/1/2010	CRT	Non-stick protective coating ¹⁴	
CV3P	3 ft. of 16/3 SEO cable pre-wired with three-prong plug for use with pre-wired cages and cross-arms ¹¹	NOM	NOM certified ⁶			

Notes

- These wattages require the REGC1 option to be chosen for shipments into California for Title 20 compliance.
- SCWA required.
- Heavy-duty anodized aluminum shroud painted to match fixture.
- Must specify CWI in Canada. 400M 480V not available with probe start.
- Optional multi-tap ballast (120, 208, 240, 277V). (120, 277, 347V in Canada).
- Consult factory for available wattages.
- Not available with 1500M.
- May be ordered as an accessory. Must specify finish.
- Ships standard with all fixtures in matching finish.
- Maximum allowable wattage lamp included.
- Must use mating receptacle, provided by others. Not available with 1500W-120V.
- HD option must be ordered.
- See www.lithonia.com/archcolors for additional color options.
- Black finish only.