



**CENTRALBIDDING**  
FROM CENTRAL AUCTION HOUSE

**5000124279 ONE TIME PURCHASE OF HORIZONTAL SELF-PRIMING  
CENTRIFUGAL PUMP FOR THE JEFFERSON PARISH DEPARTMENT OF  
SEWERAGE**

Jefferson Parish Government

Project documents obtained from [www.CentralBidding.com](http://www.CentralBidding.com)

03-Oct-2018 09:32:42 AM



# JEFFERSON PARISH

Department of Purchasing

Michael S. Yenni  
Parish President

Renny Simno  
Director

October 02, 2018

ADDENDUM # 1

Bid No.: 50-00124279

Bid Opening Date: 10/11/2018

For: ONE TIME PURCHASE OF HORIZONTAL SELF-PRIMING CENTRIFUGAL PUMP BILLS FOR  
THE JEFFEON PARISH DEPARTMENT OF SEWERAGE

---

CLARIFICATION:

**QUESTION:** Part 2.03.B states: *"The sheave/belt combination shall provide the speed ratio needed to achieve the specified pump operating conditions."*

I am unable to locate the "pump operating conditions" in either the *Description of Articles* or Specifications. Please advise me the "pump operating conditions".

**ANSWER:** Motor shall be 40 HP, 1760 RPM. Pump is 1200 GPM at 42 HD. Pump operating conditions shall be as follows: Pumps must be designed to handle raw, unscreened, domestic sanitary sewage. Pumps shall have 8" suction connection and 8" discharge connection. All internal passages, impeller vanes and recirculation port shall pass a 3 inch spherical solid.



# JEFFERSON PARISH

Department of Purchasing

**Michael S. Yenni**  
Parish President

**Renny Simno**  
Director

Sincerely,

Donna M Evans, Buyer II  
Jefferson Parish Purchasing Department

**Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form as indicated. Failure to do so will result in bid rejection.**

**This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.**