



JEFFERSON PARISH

DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR

January 7, 2021

ADDENDUM # 1

Bid Number: 50-132860

Bid Opening Date: January 14, 2021

Description of Bid: Two year contract for all labor, materials, equipment necessary to perform annual maintenance & inspections on existing air-cooled chillers for Jefferson Parish General Services.

ANSWER VENDOR QUESTIONS:

- 1) The question I had this morning was, are we changing filters and driers on the air cooled chillers, usually we only change driers and filters on air cooled chillers when the pressure drop across the drier or filter is greater than manufacturer specs. Changing those filters will require all the refrigerant to be removed from the chillers and could cause non-condensables to enter the system.

Answer: We require per the specifications for the filters and driers to be replaced.

- 2) Do you have an anticipated schedule for the chiller PM's

Answer: Each chiller is due in March of 2021

Sincerely,

Donna Reamey

Donna Reamey
Buyer II

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.

GENERAL GOVERNMENT BLDG. – 200 DERBIGNY ST., SUITE 4400, GRETN, LA 70053
OFFICE 504.364.2678

JOSEPH S. YENNI BLDG. – 1221 ELMWOOD PARK BLVD., SUITE 404, JEFFERSON, LA 70123
OFFICE 504.364.2678

EMAIL: PURCHASING@JEFFPARISH.NET WEBSITE: WWW.JEFFPARISH.NET