



CENTRALBIDDING
FROM CENTRAL AUCTION HOUSE

**5000126732 A ONE TIME PURCHASE OF (1) COMBINATION AIR VALVE
FOR THE DEPARTMENT OF DRAINAGE**
Jefferson Parish Government

Project documents obtained from www.CentralBidding.com
24-May-2019 08:33:20 AM



Bid Number 50 - 00126732

A one time purchase of (1) Combination Air Valve for the Department
of Drainage

May 29, 2019 at 11:00 am

ATTENTION VENDORS!!!

Please review all pages and respond accordingly, complying with all provisions in the technical specifications and Jefferson Parish Instructions for Bidders and General Terms and Conditions. All bids must be received in the Purchasing Department by the bid due date and time.

**Jefferson Parish Purchasing Department
200 Derbigny Street
General Government Building, Suite 4400
Gretna, LA 70053
Buyer Name: Doris Abraham, Buyer I
Buyer Email: dabraham@jeffparish.net
Buyer Phone: 504-364-2690**



JEFFERSON PARISH

Department of Purchasing

Michael S. Yenni
Parish President

Renny Simno
Director

April 24, 2019

CHANGES FOR THE JEFFERSON PARISH PURCHASING DEPARTMENT

- **Purchasing will be moving back to the General Government Building the week of May 6, 2019.**
- **All Public Bid Openings (2 pm response time) after the week of May 6, 2019 will be held in Jefferson Parish Purchasing Department, 200 Derbigny Street, Suite 4400, Gretna, LA, 70053.**
- **All advertised bid submissions (2 pm) and all non-advertised bid submissions (11 am) are due at the 200 Derbigny Street, Suite 4400 address or via on-line through Central Bidding until the date and time the bid is to open. For convenience, the bid submission can be delivered to our satellite office in the Yenni Bldg, 1221 Elmwood Park Blvd, Suite 404, Jefferson, LA, 70123 until the day before the bid opening date and time.**
- **Always refer to the Invitation to Bid instructions for pre-bid information (if applicable). Bidders should reference the "Additional Requirements" section of the bid instructions and/or the "Important Notice to Bidders" included in the bid package for specific requirements to respond accordingly.**
- **Proof of insurance in the form of a current certificate evidencing coverages is required with bid submission from all bidders. Bidders must read the insurance requirement attachment included in each bid package for specific instructions. Upon contract execution, successful bidder must produce final insurance certificates in accordance with Jefferson Parish insurance requirements.**

For more information, please call Jefferson Parish Purchasing at 504-364-2678.

Joseph S. Yenni Building – 1221 Elmwood Park Blvd., Ste. 404, Jefferson, LA 70123
Office 504.364.2678
General Government Bldg. – 200 Derbigny St – Suite 4400 - Gretna, LA 70053
Office 504.364.2678
Email: Purchasing@jeffparish.net Website: www.jeffparish.net

Nassau Valve Specifications

The intent of this specification is to define the minimum requirements of the Parish of Jefferson for the purchase and delivery of one (1) 2" APCO ASU Combination Air Valve model SCAV. A bid is a guarantee by the vendor of all specifications being met.

Submittals:

Any exception to this specification requires the vendor submit a letter attached to the documents listing in detail how it differs from the specifications. Mere attachment of brochures covering standard manufactured equipment when such differs from these specifications shall not be adequate to satisfy the letter of exceptions requirement. Such items may include

- A complete specification and submittal of all major components for the proposed valve
- One copy of all pump "Bill of Materials" of the unit's construction, cutaway drawings, and dimensions as offered to confirm compliance with the specifications.
- One descriptive brochure showing photographs and/or describing the valve.

Any bidder not able to supply information shall be considered non-responsive and shall not be accepted.

Qualifications:

1. Valve must be manufactured in the United States.

Delivery:

Freight shall be included in base bid. The valve shall be delivered to 5400 Caryota Drive, Metairie, La 70006. All deliveries shall be made during normal operating hours between 8:00 AM and 4:00 PM Monday through Friday. Deliveries will not be accepted during Jefferson parish holidays.

Specification:

1. Combination Air Valve shall be single body design and shall provide both Air Release and Air/Vacuum valve functions. Working pressures for ASU-SCAV is 150 psi (1030 kPa) and for ASU-CAV is 300 psi (2070 kPa).
2. Air release shall be accomplished by dual-range venting designed to automatically provide varied and predictable air flow over a wide range of conditions. Air release shall have a 5/16" self-adjusting orifice. The fractional air release orifice must be capable of releasing 140 scfm of air at 150 psi differential pressure.
3. Valves shall close tightly at any pressure between 2 and 150 psi for ASU-SCAV and 2 and 300 psi for ASU-CAV without leaking or spilling. The Air/Vacuum inlet and outlet areas shall meet the flow area requirements set forth in AWWA C512. In any case, the smallest cross-sectional area must define the size of the valve.

4. Valve shall have an upper body compression chamber to limit fluid level and solids interference. It shall also have a funnel shaped lower body to reduce solids buildup and allow for self-cleaning and maximum outflow.
5. A hydraulics-based float design shall be used to reduce the ballistic effect and instability of high speed fluid flow.
6. The guided float shaft shall provide smooth automatic Air Release and Air/Vacuum operation that will not foul and reduce performance on dirty service applications. To avoid loss of performance, the Air Release and Air/Vacuum seating action shall be direct driven by the shaft-mounted float. No linkages shall be used.
7. Flow deflector/splash reduction ring shall be used to restrict solids entry and minimize flow effect and splash that can cause float instability.
8. A 90 degree threaded side outlet shall be included with the valve with an extension pipe. Valves shall be capable of converting to optional vertical threaded outlet or mushroom cap without removing the valve from service and valve disassembly.
9. End connection shall be NPT.

Materials of construction:

1. Body, float, float shaft and hardware shall be 316 stainless steel
2. Piston stem and seat shall be 17-4 PH stainless steel
3. Elastomer seals shall be Acrylonitrile-butadiene (NBR)
4. Piston stem guides shall be Acetal Polyoxymethylene (POM)

Warranty:

1. Valves and actuators shall be warranted by the manufacturer for defects in materials and workmanship for a period of two years (24 months) from date of shipment.

INVITATION TO BID
THIS IS NOT AN ORDER

Page: 1

DATE: 5/22/2019

BID NO.: 50-00126732

JEFFERSON PARISH
PURCHASING DEPARTMENT
P.O. BOX 9
GRETNA, LA. 70054-0009
504-364-2678

VENDOR: *Consolidated Pipe*

BUYER: DABRAHAM@jeffparish.net

Bids will be received until 11:00 AM, 5/29/2019 via online at www.jeffparishbids.net or by hand delivery, USPS mail or other courier service to Purchasing Department, 200 Derbigny Street (General Government Building), Suite 4400, Gretna, LA 70053. For convenience, bidders may also submit bids in the East Bank Purchasing Department, Suite 404, Jefferson Parish Joseph S. Yenni Building, 1221 Elmwood Park Blvd., Jefferson LA 70123. However, if submitting bids on the day of bid opening, bidders must submit at the West Bank location only.

All bids submitted are subject to these instructions and general conditions and any special conditions and specifications contained herein, all of which are made part of this bid proposal reference. By submitting a bid, vendor agrees to comply with all provisions of Louisiana Law, as well be in compliance with the Jefferson Parish Code of Ordinances, Louisiana Code of Ethics, applicable Jefferson Parish ethical standards and Jefferson Parish Resolution No. 113646 and/or Resolution No. 113647. A copy of these resolutions may be obtained from the Office of the Parish Clerk, Suite 6700, Jefferson Parish General Government Building, 200 Derbigny Street, Gretna, LA 70053. You may also obtain a copy by visiting the Purchasing Department webpage at purchasing.jeffparish.net and clicking on On-line forms.

All vendors submitting bids should register as a Jefferson Parish vendor if not already yet registered. Registration forms may be downloaded from <http://purchasing.jeffparish.net> and by clicking on Vendor Information. Current W-9 forms with respective Tax Identification numbers and vendor applications may be submitted at any time; however, if your company is not registered and/or a current W-9 form is not on file, vendor registration is mandatory. Further, a current W-9 form and respective Tax Identification number must be supplied upon contract execution, should you be awarded a contract and/or issued purchase order. Failure to do so may result in delay of payment.

As per LSA-RS 47:301 et seq., all governmental bodies are excluded from payment of sales taxes to any Louisiana taxing body. Quotations shall be based on F.O.B. Delivered, anywhere within the Parish as designated by the Purchasing Department. JEFFERSON PARISH WILL ACCEPT ONE BID ONLY FROM EACH VENDOR. Items bid must meet specifications. JEFFERSON PARISH will accept one price for each item unless otherwise indicated. Two or more prices for one item will result in bid rejection. Bidders are required to complete, sign and return the bid form and/or complete and return the associated line item pricing forms as indicated. The price quoted for work shall be stated in figures. In the event there is a difference in unit prices and totals, the unit prices shall prevail.

JEFFERSON PARISH reserves the right to award contracts or place orders on a lump sum or individual item basis, or such combination, as shall in its judgment be in the best interest of JEFFERSON PARISH. Every contract or order shall be awarded to the LOWEST RESPONSIVE and RESPONSIBLE BIDDER, taking into consideration the CONFORMITY WITH THE SPECIFICATIONS and the DELIVERY AND/OR COMPLETION DATE

PROTESTS: Only those vendors that submitted a bid in response to this solicitation may submit a protest in writing to the Director of the Purchasing within 48 hours of bid opening. The Purchasing Director will review it in connection with the Parish Attorney's Office as appropriate and a written response will be provided as soon as possible.

JEFFERSON PARISH reserves the right to cancel all or any part of an order if not shipped promptly. No charges will be allowed for parking or cartage unless specified in the quotation. The order must not be filled at a higher price than quoted. JEFFERSON PARISH reserves the right to cancel at any time and for any reason by issuing a THIRTY (30) day written notice to the contractor.

JEFFERSON PARISH requires all products to be new (current) and all work must be performed according to standard practices for the project. Unless otherwise specified, no aftermarket parts will be accepted. Unless otherwise specified, all workmanship and materials must have at least one (1) year guaranty, in writing, from the date of delivery and/or acceptance of the project. Any deviations or alteration from the specifications must be indicated on the bid form for each item and upon request, product data for same must be submitted by the time specified by the Purchasing Department.

If this bid requires a pre-bid conference (see Additional Requirements section), bidders are advised that such conference will be held to allow bidders the opportunity to identify any discrepancies in the bid specifications and seek further clarification regarding instructions. The Purchasing Department will issue a written response to bidders' questions in the form of an Addendum.

All formal Addenda require written acknowledgment on the bid form by the bidder. Failure to acknowledge an Addendum on the bid form shall cause the bid to be rejected; JEFFERSON PARISH reserves the right to award bid to next lowest responsive and responsible bidder in this event.

USE OF BRAND NAMES AND STOCK NUMBERS: Where brand names and stock numbers are specified, it is for the purpose of establishing certain minimum standards of quality. Bids may be submitted for products of equal quality, provided brand names and stock numbers are specified. Complete product data may be required prior to award.

Quantities listed are for bidding purposes only. Actual requirements may be more or less than quantities listed.

Bidders are not to exclude from participation in, deny the benefits of, or subject to discrimination under any program or activity, any person in the United States on the grounds of race, color, national origin, or sex; nor discriminate on the basis of age under the Age Discrimination Act of 1975, or with respect to an otherwise qualified handicapped individual as provided in Section 504 of the Rehabilitation Act of 1973, or on the basis of religion, except that any exemption from such prohibition against discrimination on the basis of religion as provided in the Civil Rights Act of 1964, or Title VI and VII of the Act of April 11, 1968, shall also apply. This assurance includes compliance with the administrative requirements of the Revenue Sharing final handicapped discrimination provisions contained in Section 51.55 (c), (d), (e), and (k)(5) of the Regulations. New construction or renovation projects must comply with Section 504 of the 1973 Rehabilitation Act, as amended, in accordance with the American National Standard Institute's specifications (ANSI A117.1-1991).

Jefferson Parish and its partners as the recipients of federal funds are fully committed to awarding a contract(s) to firm(s) that will provide high quality services and that are dedicated to diversity and to containing costs. Thus, Jefferson Parish strongly encourages the involvement of minority and/or woman-owned business enterprises (DBE's, including MBE's, WBE's and SBE's) to stimulate participation in procurement and assistance programs.

INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS

IN ACCORDANCE WITH STATE REGULATIONS JEFFERSON PARISH OFFERS ELECTRONIC PROCUREMENT TO ALL VENDORS

This electronic procurement system allows vendors the convenience of reviewing and submitting bids online. This is a secure site and authorized personnel have limited read access only. Bidders are encouraged to submit electronically using this free service; while the website accepts various file types, one single PDF file containing all appropriate and required bid documents is preferred. Bidders submitting uploaded images of bid responses are solely responsible for clarity. If uploaded images/documents are not legible, then bidder's submission will be rejected. Please note all requirements contained in this bid package for electronic bid submission.

Please visit our E-Procurement Page at www.jeffparishbids.net to register and view Jefferson Parish solicitations. For more information, please visit the Purchasing Department page at <http://purchasing.jeffparish.net>.

ADDITIONAL REQUIREMENTS FOR THIS BID

PLEASE MATCH THE NUMBERS PRINTED IN THIS BOX WITH THE CORRESPONDING INSTRUCTIONS BELOW.

13

1. All bidders must attend the MANDATORY pre-bid conference and will be required to sign in and out as evidence of attendance. In accordance with LSA R.S. 38:2212(I), all prospective bidders shall be present at the beginning of the MANDATORY pre-bid conference and shall remain in attendance for the duration of the conference. Any prospective bidder who fails to attend the conference or remain for the duration shall be prohibited from submitting a bid for the project.
2. Attendance to this pre-bid conference is optional. However, failure to attend the pre-bid conference shall not relieve the bidder of responsibility for information discussed at the conference. Furthermore, failure to attend the pre-bid conference and inspection does not relieve the successful bidder from the necessity of furnishing materials or performing any work that may be required to complete the work in accordance with the specification with no additional cost to the owner.
3. Contractor must hold current applicable JEFFERSON PARISH licenses with the Department of Inspection and Code Enforcement. Contractor shall obtain any and all permits required by the JEFFERSON PARISH Department of Inspection and Code Enforcement. The contractor shall be responsible for the payment of these permits. All permits must be obtained prior to the start of the project. Contractor must also hold any and all applicable Federal and State licenses. Contractor shall be responsible for the payment of these permits and shall obtain them prior to the start of the project.
4. A LA State Contractor's License will be required in accordance with LSA R.S. 37-2150 et. seq. and such license number will be shown on the outside of the bid envelope. Failure to comply will cause the bid to be rejected. Additionally if submitting the bid electronically, then the license number must be entered in the appropriate field in the Electronic Procurement system. Failure to comply will cause the bid to be rejected.
5. It is the bidder's responsibility to visit the job site and evaluate the job before submitting a bid.
6. Job site must be clean and free of all litter and debris daily and upon completion of the contract. Passageways must be kept clean and free of material, equipment, and debris at all times. Flammable material must be removed from the job site daily because storage will not be permitted on the premises. Precautions must be exercised at all times to safeguard the welfare of JEFFERSON PARISH and the general public.

INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS

7. PUBLIC WORKS BIDS: All awards for public works in excess of \$5,000.00 will be reduced to a formal contract which shall be recorded at the contractor's expense with the Clerk of Court and Ex-Officio Recorder of Mortgages for the Parish of Jefferson. A price list of recordation costs may be obtained from the Clerk of Court and Ex-Officio Recorder of Mortgages for the Parish of Jefferson. All awards in excess of \$25,000.00 will require both a performance and a payment bond. Unless otherwise stated in the bid specifications, the performance bond requirements shall be 100% of the contract price. Unless otherwise state in the bid specifications, the payment bond requirements shall be 100% of the contract price. Both bonds shall be supplied at the signing of the contract.
8. NON-PUBLIC WORKS BIDS: A performance bond will be required for this bid. The amount of the bond will be 100% of the contract price unless otherwise indicated in the specifications. The performance bond shall be supplied at the signing of the contract.
9. NON-PUBLIC WORKS BIDS: A payment bond will be required for this bid. The amount of the bond will be 100% of the contract price unless otherwise indicated in the specifications. The payment bond shall be supplied at the signing of the contract.
10. All bidders must comply with the requirements stated in the attached "Standard Insurance Requirements" sheet attached to this bid solicitation. Prior to contract executions/purchase order issuance, the successful bidder will be required to provide final insurance certificates which shall name Jefferson Parish as an additional insured in accordance with the instructions in the aforementioned "Standard Insurance Requirements" sheet.
11. A bid bond will be required with bid submission in the amount of 5% of the total bid, unless otherwise stated in the bid specifications. Acceptable forms shall be limited to cashier's check, certified check, or surety bid bond. All sureties must be in original format (no copies). If submitting a bid online, vendors must submit an electronic bid bond through the respective online clearinghouse bond management system(s) as indicated in the electronic bid solicitation on Central Auction House. No scanned paper copies of any bid bond will be accepted as part of the electronic bid submission.
12. This is a requirements contract to be provided on an as needed basis. JEFFERSON PARISH makes no representations on warranties with regard to minimum guaranteed quantities unless otherwise stated in the bid specifications.
13. Freight charges should be included in total cost when quoting. If not quoted FOB DELIVERED, freight must be quoted as a separate item. Bid may be rejected if not quoted FOB DELIVERED or if freight charges are not indicated on bid form.
14. PUBLIC WORKS BIDS - Completed, Signed and Properly Notarized Affidavits Required; This applies to all solicitations for construction, alteration or demolition of public buildings or projects, in conformity with the provisions contained in LSA-RS 38:2212.9, LSA-RS 38:2212.10, LSA-RS 38:2224, and Sec 2-923.1 of the Jefferson Parish Code of Ordinances. For bidding purposes, all bidders must submit with bid submission COMPLETED, SIGNED and PROPERLY NOTARIZED Affidavits, including: Non-Collusion Affidavit, Non-Collusion Affidavit, Campaign Contribution Affidavit, Debt Disclosures Affidavit and E-Verify Affidavit. For the convenience of vendors, all affidavits have been combined into one form entitled PUBLIC WORKS BID AFFIDAVIT. This affidavit must be submitted in its original format, and without material alteration, in order to be compliant and for the bid to be considered responsive. A scanned copy of the completed, signed and properly notarized affidavit may be submitted with the bid, however, the successful bidder must submit the original affidavit in its original format and without material alteration upon contract execution. Failure to comply will result in the bid submission being rejected as non-responsive. The Parish reserves the right to award bid to the next lowest responsive and responsible bidder in this event.
15. NON PUBLIC WORK BIDS - Completed, Signed and Properly Notarized Affidavits Required in conformity with the provisions contained in LSA – RS 38:2224 and Sec 2-923.1 of the Jefferson Parish Code of Ordinances. For bidding purposes, all bidders must submit with bid submission COMPLETED, SIGNED and PROPERLY NOTARIZED Affidavits, including: Non-Collusion Affidavit, Debt Disclosures Affidavit and Campaign Contribution Affidavit. For the convenience of vendors, all affidavits have been combined into one form entitled NON PUBLIC WORKS BID AFFIDAVIT. This affidavit must be submitted in its original format, and without material alteration, in order to be compliant and for the bid to be considered responsive. A scanned copy of the completed, signed and properly notarized affidavit may be submitted with the bid, however, the successful bidder must submit the original affidavit in its original format and without material alteration upon contract execution. Failure to comply will result in the bid submission being rejected as non-responsive. The Parish reserves the right to award bid to the next lowest responsive and responsible bidder in this event.
16. The ensuing contract for this bid solicitation may be eligible for FEMA reimbursement and/or Federal funding/reimbursement. As such, the referenced appendix will be applicable accordingly and shall be considered a part of the bid documents. All applicable certifications must be duly completed, signed and submitted with bid submission. Failure to submit applicable certifications with bid submission will result in bid rejection.

It shall be the duty of every parish officer, employee, department, agency, special district, board, and commission; and the duty of every contractor, subcontractor, and licensee of the parish, and the duty of every applicant for certification of eligibility for a parish contract or program, to cooperate with the Inspector General in any investigation, audit, inspection, performance review, or hearing pursuant to Jefferson Parish Code of Ordinances Section 2-155.10(19). By submitting a bid, vendor acknowledges this and will abide by all provisions of the referenced Jefferson Parish Code of Ordinances.

DATE: 5/22/2019

INVITATION TO BID
THIS IS NOT AN ORDER

Page: 4

BID NO.: 50-00126732

JEFFERSON PARISH

PURCHASING DEPARTMENT
P.O. BOX 9
GRETNA, LA. 70054-0009
504-364-2678

VENDOR: Consolidated Pipe

BUYER: DABRAHAM

As per LSA-RS 47:301 et seq., all governmental bodies are excluded from payment of sales taxes to any Louisiana taxing body. Quotations shall be based on F.O.B. Agency warehouse or jobsite, anywhere within the Parish as designated by the Purchasing Department.

JEFFERSON PARISH reserves the right to cancel all or any part of an order if not shipped promptly. No charges will be allowed for parking or cartage unless specified in quotation. The order must not be filled at a higher price than quoted. JEFFERSON PARISH reserves the right to cancel at any time and for any reason by issuing a THIRTY (30) day written notice to the contractor.

JEFFERSON PARISH is expecting all products to be new and all work to be done in workman-like manner, according to standard practices. Any deviations or alteration from the specifications must be indicated on the bid form for each item and upon request, product data for same must be submitted by the time specified by the Purchasing Department.

DELIVERY: FOB JEFFERSON PARISH	
INDICATE DELIVERY DATE ON EQUIPMENT AND SUPPLIES	<u>STK-1WK</u>
INDICATE STARTING TIME (IN DAYS) FOR CONSTRUCTION WORK	_____
INDICATE COMPLETION TIME (IN DAYS) FOR CONSTRUCTION WORK	_____

In the event that addenda are issued with this bid, bidders MUST acknowledge all addenda on the bid form. Bidder must acknowledge receipt of an addendum on the bid form as indicated. Failure to acknowledge any addendum on the bid form will result in bid rejection.

Acknowledge Receipt of Addenda: NUMBER: _____
NUMBER: _____
NUMBER: _____
NUMBER: _____

LOUISIANA CONTRACTOR'S LICENSE NO.: (if applicable) _____

*** ALL BIDDERS MUST COMPLETE SECTION BELOW ***	
FIRM NAME: <u>Consolidated Pipe</u>	
SIGNATURE: <u>Tracy Mirambell</u> <small>(Must be signed here)</small>	TITLE: <u>Sales</u>
PRINT OR TYPE NAME: <u>Tracy Mirambell</u>	
ADDRESS: <u>812 Little Farms Ave.</u>	
CITY, STATE: <u>Metairie</u>	ZIP: <u>LA</u>
TELEPHONE: <u>504 737-1212</u>	FAX: <u>504 737-7909</u>
EMAIL ADDRESS: <u>tmirambell@consolidatedpipe.com</u>	

TOTAL PRICE OF ALL BID ITEMS: \$ 1,611.12

INVITATION TO BID FROM JEFFERSON PARISH - continued




BID NO.: 50-00126732

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
1	1.00	EA	<p>A one time purchase of (1) combination air valve for the Department of Drainage</p> <p>0010 - Purchase & delivery of (1) 2" APCO ASU Combination Air Valve model SCAV for Nassau Pump Station</p> <ul style="list-style-type: none"> - ASU:Style- Single body sewage combination air valve - 2:Size- 2 inch (50mm) - SCAV:Body Style - Clean or Wastewater service to 150 psi - T1:End connection -Threaded Inlet NPT, up to 300 psi - S2:Body Material - 316 Stainless Steel - R516:Orifice Size-5/16" orifice to 150PSI - NBR:Seat Seal-Acrylonitrile-Butadiene (NBR) - S2:Disc/Float material-316 Stainless Steel - S2:Shaft-316 Stainless Steel - S2:Frame Material:316 Stainless Steel <p>*FREIGHT SHALL BE INCLUDED IN BASE BID*</p> <p>SEE ATTACHED SPECIFICATIONS AND MINIMUM REQUIREMENTS **</p> <p>DELIVER TO: ELMWOOD #3 PUMP STATION 5400 CARYOTA DRIVE METAIRIE LA 70003</p> <p>CONTACT PERSON FOR ANY QUESTIONS REGARDING THIS BID IS:</p> <p>BENJAMIN LEPINE 504-736-6759 BLEPINE@JEFFPARISH.NET</p>	<p style="color: blue; font-size: 1.2em;">1611.12</p>	<p style="color: blue; font-size: 1.2em;">1,611.12</p>

PARTS LIST				
ITEM NO.	DWG. NO.	MATERIAL	DESCRIPTION	QTY.
1	27-3X	BODY	316 STAINLESS STEEL	1
2	50-16	CLAMP ASSEMBLY	316 STAINLESS STEEL	1
3	26-2X	FLANGE	316 STAINLESS STEEL	1
4	2-1X	TOP	316 STAINLESS STEEL	1
5	26-8X	BALL LEVER	316 STAINLESS STEEL	1
6	2-12	NUT	316 STAINLESS STEEL	1
7	13-11AR	BEARING PIN	316 STAINLESS STEEL	2
8	13-7R	LINK	316 STAINLESS STEEL	2
9	13-11R	BEARING PIN	316 STAINLESS STEEL	2
10	18-7A	COIL SPRING	316 STAINLESS STEEL	6
11	26-6X	VALVE LEVER	316 STAINLESS STEEL	1
12	13-19IC	LIMIT STOP	316 STAINLESS STEEL	1
13	13-4N	PLUNGER	BUNA-N & 316 S/S	1
14	13-3N	NUT	316 STAINLESS STEEL	1
15	26-5-16S	PRESSURE FULCRUM	316 STAINLESS STEEL	1
16	26-15	PRESSURE SEAT	316 STAINLESS STEEL	1
17	27-5B	LEVER FULCRUM	316 STAINLESS STEEL	2
18	27-41S	BEARING PIN	316 STAINLESS STEEL	1
19	300-6	CAP SCREW	316 STAINLESS STEEL	2
20	29E-9	FLOAT	316 STAINLESS STEEL	1
21	2-5	AIR/VAC SEAT	BUNA-N RUBBER	1
22	26-10X	BALL FULCRUM	316 STAINLESS STEEL	1
23	AS568A-107	FULCRUM O-RING	BUNA-N RUBBER	1
24	27-29	PLUG	316 STAINLESS STEEL	1
25	AS568A-163	FLANGE O-RING	BUNA-N RUBBER	1
26	26-17S	SEAT CAGE	316 STAINLESS STEEL	1
27	26-20	NUT	316 STAINLESS STEEL	1
28	13-12R	BEARING PIN	316 STAINLESS STEEL	1
29	X-DOT-B	BLUE I.D. DOT	ALUMINIUM	1
30	BLUE TAG	TAG	ALUMINIUM	1

ORIFICE DATA	
DIAMETER	WORKING PRESSURE
3/16	20-200 PSIG



SECTION A-A
SCALE 1:2

DO NOT SCALE DRAWING
 DIMENSIONS ARE IN INCHES
 UNLESS OTHERWISE SPECIFIED
 FINISHES LINEAR TOLERANCES: ±0.015
 ±0.010 PER LINEAR DIMENSION ±0.005
 ANGLES: ±0.010 PER ANGLE

Crispin Valves
 X SERIES, 2" COMBINATION AIR
 RELEASE VALVE (UNIVERSAL TYPE)

SIZE (DWG. NO.)
C UX20

REV. 1

REV.	DATE	APPROVED	DESCRIPTION	REVISIONS
1	1-16-08			